

福島県原子力発電所周辺環境放射能測定結果（速報）

平成29年度（平成30年1月）測定分

1 測定項目

(1) 空間放射線

項目	地点数	測定頻度	実施機関
空間線量率	39	連続	環境創造センター
空間積算線量	64（結果は3ヵ月毎）	3ヵ月積算	

(2) 環境試料

区分	試料名	地点数	採取頻度	採取回数 (1月)	測定試料数(1月)						実施機関	
					全β 連続 全α全β	γ	¹³¹ I	³ H	Sr	Pu		Am,Cm
大気	大気浮遊じん	17	毎月	1		17						環境創造センター
		9		1		9						
		16	毎週	5		80						
降下物	降下物	10	毎月	1		10						
陸土表土	土	15	年2回	0		0						
			年1回	0				0	0	0		
陸水上水	水	11	年4回	1		11		11				
			年1回	0				0	0			
海水	水	6(*1)	毎月	1	6	6		6	6	6		
		2(*2)	年4回	0	0	0		0				
			年1回	0				0	0			
海底土	海底土	6(*1)	年4回	0		0			0	0		
		2(*2)	年4回	0		0						
			年1回	0				0	0			
指標植物	松葉	15	年4回	0		0	0					

*1 東京電力ホールディングス（株）福島第一原子力発電所周辺海域

*2 東京電力ホールディングス（株）福島第二原子力発電所周辺海域

2 測定項目（比較対照地点調査）

(1) 空間放射線

項目	地点数	測定頻度	実施機関
空間線量率	3	連続	環境創造センター

(2) 環境試料

区分	試料名	地点数	採取頻度	採取回数 (1月)	測定試料数(1月)						実施機関	
					全β	γ	¹³¹ I	³ H	Sr	Pu		Am,Cm
大気	大気浮遊じん	7	毎月	1		7						環境創造センター
	大気中水分	1		1			1					
降下物	降下物	2	毎月	1		2						
陸土表土	土	7	年1回	0		0			0	0	0	
陸水上水	水	2	年1回	0		0		0	0	0		
海水	水	1	年1回	0	0	0		0	0	0		
海底土	海底土	1	年1回	0		0			0	0		
指標植物	松葉	5	年4回	0		0	0					

(注)次ページ以降の黄色網掛け部分が、今回の公表分です。

第5 原子力発電所周辺環境放射能測定値一覧表

5-1 空間放射線

5-1-1 空間線量率

No.	測定年月 測定項目 測定地点名	H29.4		5		6		7		8		9		10		11		12		H30.1		2		3	
		線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間
1	いわき市 小川	54 (65)	720	51 (67)	744	50 (66)	720	51 (80)	744	50 (63)	744	52 (67)	720	53 (87)	744	54 (70)	713	54 (68)	744	54 (66)	744				
2	いわき市 久之浜	88 (94)	720	88 (99)	744	88 (96)	720	87 (105)	744	86 (92)	744	86 (102)	720	85 (105)	744	85 (94)	712	84 (97)	744	84 (95)	744				
3	いわき市 下補光	59 (70)	720	59 (79)	744	59 (72)	720	59 (87)	744	58 (70)	744	58 (76)	720	58 (71)	744	58 (71)	720	57 (82)	739	53 (69)	744				
4	いわき市 川前	69 (84)	720	70 (84)	744	69 (82)	720	70 (103)	744	68 (87)	744	68 (88)	720	68 (82)	744	69 (83)	713	69 (88)	744	67 (78)	744				
5	田村市 都路馬洗戸	97 (107)	720	98 (113)	744	97 (109)	720	97 (133)	744	94 (109)	744	94 (108)	720	93 (107)	744	93 (108)	713	89 (109)	744	81 (106)	744				
6	広野町 二ツ沼	100 (126)	720	100 (120)	744	99 (115)	720	98 (124)	744	95 (119)	744	96 (123)	720	94 (124)	737	95 (123)	720	95 (130)	744	93 (107)	744				
7	広野町 小滝立	93 (106)	720	94 (114)	744	93 (101)	720	92 (112)	744	90 (102)	744	90 (111)	720	89 (119)	744	90 (103)	714	89 (101)	744	88 (102)	744				
8	楡葉町 山田岡	70 (82)	720	71 (88)	744	70 (85)	720	72 (92)	743	70 (83)	741	69 (89)	720	68 (95)	744	68 (85)	720	67 (84)	744	67 (81)	743				
9	楡葉町 木戸ダム	114 (129)	720	116 (131)	744	115 (125)	720	115 (140)	744	111 (126)	744	110 (130)	720	109 (128)	744	108 (122)	714	105 (128)	744	102 (127)	744				
10	楡葉町 繁岡	218 (227)	720	214 (233)	744	214 (227)	720	213 (235)	741	208 (226)	744	208 (232)	720	207 (232)	744	211 (224)	720	212 (236)	744	205 (225)	741				
11	楡葉町 松館	243 (254)	720	240 (266)	744	235 (248)	720	208 (239)	744	199 (216)	744	200 (231)	720	197 (223)	738	199 (211)	720	197 (224)	744	194 (209)	744				
12	楡葉町 波倉	284 (292)	720	284 (296)	744	282 (293)	720	278 (297)	741	271 (281)	744	271 (288)	720	269 (279)	744	271 (282)	720	273 (290)	744	265 (282)	741				

単位:線量率:μSv/h 測定時間:h
上段:平均値 (下段):最大値

No.	測定年月 測定項目 測定地点名	H29.4		5		6		7		8		9		10		11		12		H30.1		2		3	
		線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間
28	浪江町 請 ^う 戸 ^こ *1	124 (143)	720	127 (140)	744	125 (142)	720	127 (150)	744	124 (143)	744	120 (136)	720	117 (141)	744	117 (138)	720	114 (130)	744	109 (131)	744				
29	浪江町 棚 ^な し ^し 塩 ^し *1	84 (98)	720	86 (102)	744	84 (99)	720	86 (120)	744	84 (100)	744	84 (100)	717	81 (111)	744	82 (103)	720	80 (98)	744	77 (105)	744				
30	浪江町 浪 ^な 江 ^か	173 (181)	720	173 (181)	744	170 (183)	720	171 (189)	744	166 (179)	742	165 (174)	720	160 (178)	739	161 (174)	720	158 (172)	744	153 (167)	744				
31	浪江町 幾 ^い 世 ^せ 橋 ^{はし}	112 (125)	720	112 (124)	744	109 (120)	720	110 (133)	740	106 (117)	744	105 (117)	720	103 (123)	740	103 (116)	720	101 (116)	744	99 (115)	744				
32	浪江町 大 ^お 柿 ^{かき} ダ ^た ム	890 (912)	720	890 (915)	744	884 (905)	720	893 (924)	744	877 (905)	744	875 (896)	720	842 (881)	744	832 (859)	713	811 (830)	740	786 (823)	744				
33	浪江町 南 ^な 津 ^つ 島 ^{しま}	1,350 (1,420)	720	1,370 (1,450)	744	1,350 (1,410)	720	1,330 (1,430)	744	1,280 (1,370)	744	1,290 (1,340)	720	1,250 (1,350)	744	1,270 (1,340)	714	1,170 (1,230)	744	1,040 (1,180)	744				
34	葛尾村 夏 ^{なつ} 湯 ^ゆ	162 (172)	720	162 (177)	744	161 (179)	720	161 (189)	744	156 (168)	744	156 (175)	720	154 (179)	744	155 (168)	712	153 (168)	744	142 (167)	744				
35	南相馬市 泉 ^{いづみ} 次 ^{つぎ}	135 (147)	720	135 (152)	744	132 (148)	720	133 (162)	744	126 (144)	744	127 (143)	720	125 (149)	744	126 (139)	714	125 (143)	744	122 (141)	744				
36	南相馬市 横 ^{よこ} 川 ^{がわ} ダ ^た ム	273 (286)	720	275 (288)	744	272 (283)	720	272 (293)	744	261 (276)	744	264 (273)	720	259 (274)	744	262 (271)	713	250 (263)	744	242 (264)	744				
37	南相馬市 蘆 ^{あし} 浜 ^{はま}	46 (66)	720	46 (72)	744	46 (66)	720	47 (88)	741	45 (62)	744	46 (63)	720	46 (65)	744	46 (60)	720	46 (66)	744	46 (65)	741				
38	飯館村 伊 ^い 丹 ^{たん} 次 ^{つぎ}	234 (249)	720	236 (251)	744	239 (258)	720	232 (255)	739	225 (245)	744	232 (242)	720	241 (288)	744	183 (246)	720	177 (198)	744	158 (204)	740				
39	川俣町 山 ^{やま} 木 ^き 屋 ^や	170 (185)	720	171 (187)	744	169 (181)	720	163 (193)	740	157 (169)	744	158 (168)	720	155 (170)	744	156 (181)	720	147 (164)	744	126 (152)	740				

(注) 1 No.の網掛け部分は東京電力株式会社福島第一原子力発電所から半径5km未満の地域

2 *1 可搬型モニタリングポストによる測定

3 *2 空間線量率の測定はモニタリングポスト (NaIシンチレーション検出器、単位：ナノグレイ/時) により行ったが、概ね10,000nGy/h (10μGy/h)を超えた場合は、併設している高線量用モニタリングポスト (電離箱検出器、単位：ナノグレイ/時) の測定値で補完した。

5-2 環境放射線

5-2-1 大気浮遊じん中の全アルファ放射能及び全ベータ放射能

単位:線量率:Bq/m³ 測定時間:h
上段:平均値(下段):最大値

No.	測定地点名	測定年月																						
		H29.4		5		6		7		8		9		10		11		12		H30.1		3		
測定項目		測定 時間	測定 値	測定 時間	測定 値	測定 時間	測定 値	測定 時間	測定 値	測定 時間	測定 値	測定 時間	測定 値	測定 時間	測定 値	測定 時間	測定 値	測定 時間	測定 値	測定 時間	測定 値	測定 時間	測定 値	
1	いわき市 <small>いわき市</small>	全アルファ 放射能	720	0.043 (0.23)	744	0.036 (0.26)	720	0.045 (0.20)	660	0.033 (0.19)	744	0.031 (0.15)	720	0.033 (0.13)	744	0.036 (0.12)	720	0.033 (0.18)	744	0.028 (0.17)	744	0.028 (0.17)	744	0.028 (0.17)
		全ベータ 放射能	720	0.065 (0.34)	744	0.058 (0.32)	720	0.068 (0.29)	660	0.052 (0.24)	744	0.052 (0.19)	720	0.053 (0.16)	744	0.058 (0.16)	720	0.054 (0.22)	744	0.048 (0.22)	744	0.048 (0.22)	744	0.048 (0.22)
2	田村市 <small>たむら市</small>	全アルファ 放射能	720	0.016 (0.070)	690	0.017 (0.11)	660	0.017 (0.072)	732	0.011 (0.056)	744	0.014 (0.087)	720	0.013 (0.054)	744	0.013 (0.061)	720	0.009 (0.041)	744	0.004 (0.035)	744	0.004 (0.035)	744	0.004 (0.035)
		全ベータ 放射能	720	0.038 (0.11)	690	0.038 (0.17)	660	0.040 (0.12)	732	0.031 (0.097)	744	0.036 (0.14)	720	0.035 (0.090)	744	0.034 (0.10)	720	0.029 (0.074)	744	0.022 (0.066)	744	0.022 (0.066)	744	0.022 (0.066)
3	広野町 <small>ひろの町</small>	全アルファ 放射能	720	0.016 (0.061)	744	0.020 (0.10)	648	0.025 (0.13)	744	0.016 (0.079)	732	0.018 (0.075)	720	0.016 (0.054)	744	0.017 (0.054)	720	0.013 (0.045)	744	0.009 (0.048)	744	0.009 (0.048)	744	0.009 (0.048)
		全ベータ 放射能	720	0.038 (0.10)	744	0.043 (0.16)	648	0.053 (0.20)	744	0.038 (0.13)	732	0.042 (0.13)	720	0.039 (0.096)	744	0.040 (0.10)	720	0.035 (0.086)	744	0.029 (0.085)	744	0.029 (0.085)	744	0.029 (0.085)
4	楢葉町 <small>のば町</small>	全アルファ 放射能	720	0.024 (0.099)	732	0.027 (0.14)	720	0.030 (0.10)	684	0.024 (0.12)	744	0.024 (0.098)	708	0.024 (0.084)	744	0.025 (0.10)	636	0.018 (0.075)	744	0.011 (0.063)	744	0.011 (0.063)	744	0.011 (0.063)
		全ベータ 放射能	720	0.046 (0.14)	732	0.050 (0.18)	720	0.053 (0.14)	684	0.045 (0.16)	744	0.045 (0.13)	708	0.046 (0.13)	744	0.047 (0.15)	636	0.038 (0.11)	744	0.029 (0.097)	744	0.029 (0.097)	744	0.029 (0.097)
5	楢葉町 <small>のば町</small>	全アルファ 放射能	720	0.028 (0.19)	744	0.027 (0.23)	660	0.033 (0.20)	744	0.018 (0.18)	744	0.022 (0.18)	720	0.016 (0.12)	744	0.028 (0.14)	720	0.023 (0.11)	744	0.017 (0.15)	744	0.017 (0.15)	744	0.017 (0.15)
		全ベータ 放射能	720	0.057 (0.33)	744	0.057 (0.37)	660	0.066 (0.34)	744	0.041 (0.31)	744	0.049 (0.30)	720	0.039 (0.22)	744	0.059 (0.25)	720	0.049 (0.19)	744	0.040 (0.26)	744	0.040 (0.26)	744	0.040 (0.26)
6	富岡町 <small>とみおか町</small>	全アルファ 放射能	678	0.022 (0.13)	744	0.019 (0.14)	708	0.023 (0.17)	744	0.014 (0.082)	744	0.017 (0.088)	720	0.015 (0.061)	666	0.023 (0.086)	720	0.020 (0.091)	744	0.016 (0.099)	744	0.016 (0.099)	744	0.016 (0.099)
		全ベータ 放射能	678	0.076 (0.39)	744	0.069 (0.40)	708	0.080 (0.49)	744	0.051 (0.24)	744	0.061 (0.26)	720	0.057 (0.19)	666	0.083 (0.26)	720	0.073 (0.28)	744	0.061 (0.30)	744	0.061 (0.30)	744	0.061 (0.30)
7	川内村 <small>かわうち村</small>	全アルファ 放射能	708	0.034 (0.14)	732	0.033 (0.17)	720	0.038 (0.17)	672	0.028 (0.16)	732	0.032 (0.13)	708	0.032 (0.14)	744	0.038 (0.20)	720	0.027 (0.11)	720	0.013 (0.11)	744	0.013 (0.11)	744	0.013 (0.11)
		全ベータ 放射能	708	0.058 (0.18)	732	0.057 (0.23)	720	0.063 (0.23)	672	0.049 (0.21)	732	0.056 (0.20)	708	0.056 (0.21)	744	0.063 (0.29)	720	0.050 (0.17)	720	0.031 (0.15)	744	0.031 (0.15)	744	0.031 (0.15)
8	大郷町 <small>おほご町</small>	全アルファ 放射能	720	0.018 (0.095)	744	0.017 (0.11)	708	0.021 (0.11)	744	0.011 (0.087)	744	0.016 (0.11)	720	0.012 (0.043)	696	0.018 (0.069)	720	0.012 (0.053)	744	0.008 (0.058)	744	0.008 (0.058)	744	0.008 (0.058)
		全ベータ 放射能	720	0.072 (0.30)	744	0.070 (0.32)	708	0.084 (0.34)	744	0.053 (0.28)	744	0.066 (0.34)	720	0.058 (0.16)	696	0.075 (0.24)	720	0.056 (0.18)	744	0.046 (0.19)	744	0.046 (0.19)	744	0.046 (0.19)

No.	測定地名	測定年月																								
		H28.4		5		6		7		8		9		10		11		12		H30.1		2		3		
	測定項目	測定値	測定時間	測定値	測定時間	測定値	測定時間	測定値	測定時間	測定値	測定時間	測定値	測定時間	測定値	測定時間	測定値	測定時間	測定値	測定時間	測定値	測定時間	測定値	測定時間	測定値	測定時間	
9	大瀬町 去 ^ち と ^と 次	全アルファ	0.018	720	0.021	732	0.016	684	0.021	744	0.011	744	0.018	720	0.015	696	0.020	720	0.014	744	0.010	744	0.053	744		
		放射能	(0.11)	(0.13)	(0.073)	(0.16)	(0.070)	(0.11)	(0.078)	(0.38)	(0.24)	(0.056)	(0.092)	(0.11)	(0.092)	(0.19)	(0.051)	(0.075)	(0.26)	(0.056)	(0.18)	(0.037)	(0.065)	(0.053)	(0.18)	
10	双葉町 郡 ^お り ^き 山	全アルファ	0.015	720	0.022	732	0.014	654	0.020	744	0.010	744	0.015	720	0.013	720	0.015	720	0.010	744	0.008	744	0.023	744		
		放射能	(0.073)	(0.11)	(0.068)	(0.13)	(0.068)	(0.042)	(0.20)	(0.042)	(0.14)	(0.092)	(0.14)	(0.092)	(0.047)	(0.046)	(0.077)	(0.084)	(0.059)	(0.034)	(0.034)	(0.037)	(0.065)	(0.023)	(0.065)	
11	浪江町 畿 ^上 世 ^し 桶	全アルファ	0.023	720	0.033	744	0.025	720	0.028	672	0.016	744	0.022	720	0.020	744	0.028	720	0.018	744	0.014	744	0.032	744		
		放射能	(0.088)	(0.20)	(0.056)	(0.15)	(0.14)	(0.21)	(0.049)	(0.21)	(0.091)	(0.033)	(0.17)	(0.042)	(0.13)	(0.080)	(0.12)	(0.17)	(0.12)	(0.059)	(0.094)	(0.068)	(0.032)	(0.10)		
12	浪江町 大 ^{おお} 船 ^{ふね} ダム	全アルファ	0.032	708	0.038	744	0.036	624	0.043	744	0.030	744	0.038	720	0.034	744	0.045	720	0.034	744	0.026	744	0.042	744		
		放射能	(0.14)	(0.14)	(0.14)	(0.24)	(0.35)	(0.32)	(0.28)	(0.39)	(0.18)	(0.25)	(0.25)	(0.25)	(0.25)	(0.21)	(0.21)	(0.32)	(0.32)	(0.23)	(0.13)	(0.098)	(0.18)	(0.18)		
13	勸修寺 夏 ^{なつ} の ^{なつ} 湯	全アルファ	0.061	720	0.068	732	0.055	672	0.060	732	0.031	744	0.045	720	0.039	744	0.055	720	0.038	744	0.021	744	0.042	744		
		放射能	(0.34)	(0.37)	(0.32)	(0.28)	(0.44)	(0.39)	(0.28)	(0.39)	(0.18)	(0.26)	(0.26)	(0.26)	(0.26)	(0.17)	(0.17)	(0.20)	(0.20)	(0.17)	(0.23)	(0.17)	(0.23)	(0.23)	(0.23)	
14	藤相馬市 イ ^い サ ^さ ス ^す 次	全アルファ	0.020	708	0.025	744	0.018	660	0.024	744	0.012	744	0.017	720	0.014	744	0.019	720	0.015	744	0.011	744	0.029	744		
		放射能	(0.095)	(0.10)	(0.080)	(0.11)	(0.12)	(0.16)	(0.11)	(0.11)	(0.061)	(0.090)	(0.13)	(0.13)	(0.090)	(0.051)	(0.051)	(0.056)	(0.056)	(0.045)	(0.064)	(0.064)	(0.095)	(0.095)	(0.095)	
15	藤相馬市 い ^い ば ^ば 茨	全アルファ	0.021	720	0.026	744	0.016	720	0.022	732	0.008	744	0.016	720	0.013	744	0.020	720	0.017	744	0.013	732	0.057	732		
		放射能	(0.12)	(0.13)	(0.10)	(0.11)	(0.052)	(0.091)	(0.066)	(0.30)	(0.18)	(0.040)	(0.030)	(0.030)	(0.030)	(0.020)	(0.020)	(0.025)	(0.24)	(0.073)	(0.084)	(0.020)	(0.020)	(0.020)	(0.020)	
16	飯沼村 伊 ^い ノ ^の 丹 ^に 次	全アルファ	0.013	720	0.016	744	0.015	708	0.012	720	0.006	744	0.010	720	0.011	732	0.010	720	0.006	744	0.003	732	0.031	732		
		放射能	(0.14)	(0.083)	(0.14)	(0.10)	(0.14)	(0.10)	(0.10)	(0.10)	(0.037)	(0.058)	(0.058)	(0.058)	(0.058)	(0.068)	(0.068)	(0.065)	(0.065)	(0.037)	(0.078)	(0.020)	(0.078)	(0.078)	(0.078)	
17	川俣町 山 ^{やま} 木 ^き 屋	全アルファ	0.016	720	0.023	744	0.021	708	0.016	732	0.006	744	0.014	720	0.012	732	0.012	720	0.009	744	0.004	732	0.037	732		
		放射能	(0.096)	(0.16)	(0.10)	(0.14)	(0.10)	(0.14)	(0.14)	(0.14)	(0.027)	(0.087)	(0.087)	(0.087)	(0.087)	(0.058)	(0.058)	(0.083)	(0.038)	(0.038)	(0.027)	(0.078)	(0.027)	(0.10)		

注) 1 No.の欄付け部分は東京電力株式会社福島第一原子力発電所から半径5km圏内の区域

No.	地点名	採取期間	核種濃度 (mBq/m ³)															
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce					
10	双葉町 郡山 (連続ダストモニタ)	H29. 4. 1 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.21	1.4	ND		
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.078	0.55	ND		
		H29. 6. 1 ~ H29. 7. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.051	0.37	ND		
		H29. 7. 1 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.12	0.88	ND		
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.073	0.56	ND		
		H29. 9. 1 ~ H29.10. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.15	1.2	ND		
		H29.10. 1 ~ H29.11. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.073	0.62	ND		
		H29.11. 1 ~ H29.12. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.056	0.47	ND		
		H29.12. 1 ~ H30. 1. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.024	0.23	ND		
		H30. 1. 1 ~ H30. 2. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.066	0.57	ND		
		11	浪江町 幾世橋 (連続ダストモニタ)	H29. 4. 1 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.012	0.081	ND
				H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.012	0.090	ND
H29. 6. 1 ~ H29. 7. 1	ND			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.036	ND		
H29. 7. 1 ~ H29. 8. 1	ND			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.012	0.082	ND		
H29. 8. 1 ~ H29. 9. 1	ND			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.031	ND		
H29. 9. 1 ~ H29.10. 1	ND			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.007	0.050	ND		
H29.10. 1 ~ H29.11. 1	ND			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.032	ND		
H29.11. 1 ~ H29.12. 1	ND			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.006	0.050	ND		
H29.12. 1 ~ H30. 1. 1	ND			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.032	ND	
H30. 1. 1 ~ H30. 2. 1	ND			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.032	0.032	ND	
12	浪江町 大柁ダム (連続ダストモニタ)			H29. 4. 1 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.010	0.067	ND
				H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.018	0.12	ND
		H29. 6. 1 ~ H29. 7. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.009	0.065	ND		
		H29. 7. 1 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.009	0.072	ND		
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.010	0.087	ND		
		H29. 9. 1 ~ H29.10. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.009	0.074	ND		
		H29.10. 1 ~ H29.11. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.006	0.040	ND		
		H29.11. 1 ~ H29.12. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.006	0.048	ND		
		H29.12. 1 ~ H30. 1. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.025	0.22	ND		
		H30. 1. 1 ~ H30. 2. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.017	0.13	ND		

No.	地点名	採取期間	核種濃度 (mBq/m ³)															
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce					
25	浪江町 みなまのしま 南津島 (リアルタイム ダストモニタ)	H29. 4. 1 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.18	ND	ND	
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.095	ND	ND
		H29. 6. 1 ~ H29. 7. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.053	ND	ND
		H29. 7. 1 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.078	ND	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.059	ND	ND
		H29. 9. 1 ~ H29.10. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.034	ND	0.13	ND	ND
		H29.10. 1 ~ H29.11. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.035	ND	ND
		H29.11. 1 ~ H29.12. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.036	ND	ND
		H29.12. 1 ~ H30. 1. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.040	ND	ND
		H30. 1. 1 ~ H30. 2. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.035	ND	ND
		H29. 4. 1 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.039	ND	0.063	ND	ND
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.062	ND	ND
		H29. 6. 1 ~ H29. 7. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.073	ND	ND
H29. 7. 1 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.088	ND	ND		
H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.078	ND	ND		
H29. 9. 1 ~ H29.10. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.093	ND	ND		
H29.10. 1 ~ H29.11. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.085	ND	ND		
H29.11. 1 ~ H29.12. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.028	ND	ND		
H29.12. 1 ~ H30. 1. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.039	ND	ND		
H30. 1. 1 ~ H30. 2. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.052	ND	ND		
26	南相馬市 よこがわ 横川ダム (リアルタイム ダストモニタ)	H29. 4. 1 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.063	ND	ND	
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.062	ND	ND	
		H29. 6. 1 ~ H29. 7. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.073	ND	ND	
		H29. 7. 1 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.088	ND	ND	
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.078	ND	ND	
		H29. 9. 1 ~ H29.10. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.093	ND	ND	
		H29.10. 1 ~ H29.11. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.085	ND	ND	
		H29.11. 1 ~ H29.12. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.028	ND	ND	
		H29.12. 1 ~ H30. 1. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.039	ND	ND	
		H30. 1. 1 ~ H30. 2. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.052	ND	ND	

No.	地点名	採取期間	核種濃度 (mBq/m ³)														
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce				
		H29. 3. 31 ~ H29. 4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 6 ~ H29. 4. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 13 ~ H29. 4. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 20 ~ H29. 4. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 27 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 2 ~ H29. 5. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 11 ~ H29. 5. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 18 ~ H29. 5. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 25 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 1 ~ H29. 6. 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 8 ~ H29. 6. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 15 ~ H29. 6. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 22 ~ H29. 6. 29	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 29 ~ H29. 7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 6 ~ H29. 7. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 13 ~ H29. 7. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 20 ~ H29. 7. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 27 ~ H29. 8. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 3 ~ H29. 8. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 10 ~ H29. 8. 17	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 17 ~ H29. 8. 24	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 24 ~ H29. 8. 31	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 31 ~ H29. 9. 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 7 ~ H29. 9. 14	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 14 ~ H29. 9. 21	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 21 ~ H29. 9. 28	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 28 ~ H29. 10. 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 5 ~ H29. 10. 12	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 12 ~ H29. 10. 19	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 19 ~ H29. 10. 26	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 26 ~ H29. 11. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 2 ~ H29. 11. 9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 9 ~ H29. 11. 16	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 16 ~ H29. 11. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 22 ~ H29. 11. 30	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

27 広野町
二ツ沼
(ダストサンプラー)

No.	地点名	採取期間	核種濃度 (mBq/m ³)														
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce				
		H29. 3. 31 ~ H29. 4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 6 ~ H29. 4. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 13 ~ H29. 4. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 20 ~ H29. 4. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 27 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 2 ~ H29. 5. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 11 ~ H29. 5. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 18 ~ H29. 5. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 25 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 1 ~ H29. 6. 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 8 ~ H29. 6. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 15 ~ H29. 6. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 22 ~ H29. 6. 29	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 29 ~ H29. 7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 6 ~ H29. 7. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 13 ~ H29. 7. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 20 ~ H29. 7. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 27 ~ H29. 8. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 3 ~ H29. 8. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 10 ~ H29. 8. 17	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 17 ~ H29. 8. 24	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 24 ~ H29. 8. 31	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 31 ~ H29. 9. 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 7 ~ H29. 9. 14	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 14 ~ H29. 9. 21	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 21 ~ H29. 9. 28	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 28 ~ H29. 10. 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 5 ~ H29. 10. 12	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 12 ~ H29. 10. 19	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 19 ~ H29. 10. 26	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 26 ~ H29. 11. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 2 ~ H29. 11. 9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 9 ~ H29. 11. 16	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 16 ~ H29. 11. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 22 ~ H29. 11. 30	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

28
 榎葉町
ヤマダ山田岡
 (ダストサンプラー)

No.	地点名	採取期間	核種濃度 (mBq/m ³)														
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce				
		H29. 3. 31 ~ H29. 4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 6 ~ H29. 4. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 13 ~ H29. 4. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 20 ~ H29. 4. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 27 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 2 ~ H29. 5. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 11 ~ H29. 5. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 18 ~ H29. 5. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 25 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 1 ~ H29. 6. 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 8 ~ H29. 6. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 15 ~ H29. 6. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 22 ~ H29. 6. 29	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 29 ~ H29. 7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 6 ~ H29. 7. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 13 ~ H29. 7. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 20 ~ H29. 7. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 27 ~ H29. 8. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 3 ~ H29. 8. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 10 ~ H29. 8. 17	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 17 ~ H29. 8. 24	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 24 ~ H29. 8. 31	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 31 ~ H29. 9. 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 7 ~ H29. 9. 14	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 14 ~ H29. 9. 21	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 21 ~ H29. 9. 28	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 28 ~ H29. 10. 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 5 ~ H29. 10. 12	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 12 ~ H29. 10. 19	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 19 ~ H29. 10. 26	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 26 ~ H29. 11. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 2 ~ H29. 11. 9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 9 ~ H29. 11. 16	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 16 ~ H29. 11. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 22 ~ H29. 11. 30	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

29
 榑葉町
 松館
 (ダストサンプラー)

No.	地点名	採取期間	核種濃度 (mBq/m ³)														
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce				
		H29. 3. 31 ~ H29. 4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 6 ~ H29. 4. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 13 ~ H29. 4. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 20 ~ H29. 4. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 27 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 2 ~ H29. 5. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 11 ~ H29. 5. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 18 ~ H29. 5. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 25 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 1 ~ H29. 6. 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 8 ~ H29. 6. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 15 ~ H29. 6. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 22 ~ H29. 6. 29	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 29 ~ H29. 7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 6 ~ H29. 7. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 13 ~ H29. 7. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 20 ~ H29. 7. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 27 ~ H29. 8. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 3 ~ H29. 8. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 10 ~ H29. 8. 17	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 17 ~ H29. 8. 24	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 24 ~ H29. 8. 31	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 31 ~ H29. 9. 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 7 ~ H29. 9. 14	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 14 ~ H29. 9. 21	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 21 ~ H29. 9. 28	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 28 ~ H29. 10. 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 5 ~ H29. 10. 12	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 12 ~ H29. 10. 19	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 19 ~ H29. 10. 26	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 26 ~ H29. 11. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 2 ~ H29. 11. 9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 9 ~ H29. 11. 16	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 16 ~ H29. 11. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 22 ~ H29. 11. 30	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

30 榑葉町
波倉
(ダストサンプラー)

No.	地点名	採取期間	核種濃度 (mBq/m ³)														
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce				
		H29. 3. 31 ~ H29. 4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 6 ~ H29. 4. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 13 ~ H29. 4. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 20 ~ H29. 4. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 27 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 2 ~ H29. 5. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 11 ~ H29. 5. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 18 ~ H29. 5. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 25 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 1 ~ H29. 6. 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 8 ~ H29. 6. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 15 ~ H29. 6. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 22 ~ H29. 6. 29	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 29 ~ H29. 7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 6 ~ H29. 7. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 13 ~ H29. 7. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 20 ~ H29. 7. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 27 ~ H29. 8. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 3 ~ H29. 8. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 10 ~ H29. 8. 17	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 17 ~ H29. 8. 24	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 24 ~ H29. 8. 31	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 31 ~ H29. 9. 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 7 ~ H29. 9. 14	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 14 ~ H29. 9. 21	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 21 ~ H29. 9. 28	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 28 ~ H29. 10. 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 5 ~ H29. 10. 12	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 12 ~ H29. 10. 19	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 19 ~ H29. 10. 26	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 26 ~ H29. 11. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 2 ~ H29. 11. 9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 9 ~ H29. 11. 16	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 16 ~ H29. 11. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 22 ~ H29. 11. 30	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

富岡町
がみこほりやま
 上郡山
 (ダストサンプ
 ラー)*1

No.	地点名	採取期間	核種濃度 (mBq/m ³)														
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce				
		H29. 3. 31 ~ H29. 4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 6 ~ H29. 4. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 13 ~ H29. 4. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 20 ~ H29. 4. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 27 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 2 ~ H29. 5. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 11 ~ H29. 5. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 18 ~ H29. 5. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 25 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 1 ~ H29. 6. 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 8 ~ H29. 6. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 15 ~ H29. 6. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 22 ~ H29. 6. 29	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 29 ~ H29. 7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 6 ~ H29. 7. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 13 ~ H29. 7. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 20 ~ H29. 7. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 27 ~ H29. 8. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 3 ~ H29. 8. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 10 ~ H29. 8. 17	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 17 ~ H29. 8. 24	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 24 ~ H29. 8. 31	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 31 ~ H29. 9. 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 7 ~ H29. 9. 14	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 14 ~ H29. 9. 21	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 21 ~ H29. 9. 28	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 28 ~ H29. 10. 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 5 ~ H29. 10. 12	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 12 ~ H29. 10. 19	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 19 ~ H29. 10. 26	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 26 ~ H29. 11. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 2 ~ H29. 11. 9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 9 ~ H29. 11. 16	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 16 ~ H29. 11. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 22 ~ H29. 11. 30	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

富岡町
しもと郡りやま
 下郡山
 (ダストサンプラー)

No.	地点名	採取期間	核種濃度 (mBq/m ³)														
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce				
		H29. 3. 31 ~ H29. 4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 6 ~ H29. 4. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 13 ~ H29. 4. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 20 ~ H29. 4. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 27 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 2 ~ H29. 5. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 11 ~ H29. 5. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.28	ND	ND
		H29. 5. 18 ~ H29. 5. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 25 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 1 ~ H29. 6. 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 8 ~ H29. 6. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 15 ~ H29. 6. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 22 ~ H29. 6. 29	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 29 ~ H29. 7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 6 ~ H29. 7. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 13 ~ H29. 7. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 20 ~ H29. 7. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 27 ~ H29. 8. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 3 ~ H29. 8. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 10 ~ H29. 8. 17	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.18	ND	ND
		H29. 8. 17 ~ H29. 8. 24	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 24 ~ H29. 8. 31	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 31 ~ H29. 9. 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 7 ~ H29. 9. 14	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 14 ~ H29. 9. 21	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.25	ND	ND
		H29. 9. 21 ~ H29. 9. 28	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 28 ~ H29. 10. 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 5 ~ H29. 10. 12	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.21	ND	ND
		H29. 10. 12 ~ H29. 10. 19	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.77	ND	ND
		H29. 10. 19 ~ H29. 10. 26	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.23	ND	ND
		H29. 10. 26 ~ H29. 11. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.42	ND	ND
		H29. 11. 2 ~ H29. 11. 9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.52	ND	ND
		H29. 11. 9 ~ H29. 11. 16	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.60	ND	ND
		H29. 11. 16 ~ H29. 11. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.30	ND	ND
		H29. 11. 22 ~ H29. 11. 30	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.49	ND	ND

富岡町
 夜の森
 (ダストサンプラー)

No.	地点名	採取期間	核種濃度 (mBq/m ³)													
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce			
		H29. 11. 30 ~ H29. 12. 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 12. 7 ~ H29. 12. 14	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.33	ND
		H29. 12. 14 ~ H29. 12. 21	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.41	ND
		H29. 12. 21 ~ H29. 12. 28	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.25	ND
		H29. 12. 28 ~ H30. 1. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.42	ND
		H30. 1. 4 ~ H30. 1. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30. 1. 11 ~ H30. 1. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.30	ND
		H30. 1. 18 ~ H30. 1. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30. 1. 25 ~ H30. 2. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.16	ND

No.	地点名	採取期間	核種濃度 (mBq/m ³)															
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce					
		H29. 3. 31 ~ H29. 4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.20	ND	ND
		H29. 4. 6 ~ H29. 4. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.22	ND	ND
		H29. 4. 13 ~ H29. 4. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.28	ND	ND
		H29. 4. 20 ~ H29. 4. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.36	ND	ND
		H29. 4. 27 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.23	ND	ND
		H29. 5. 2 ~ H29. 5. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.19	ND	ND
		H29. 5. 11 ~ H29. 5. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.39	ND	ND
		H29. 5. 18 ~ H29. 5. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.51	ND	ND
		H29. 5. 25 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.53	ND	ND
		H29. 6. 1 ~ H29. 6. 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.19	ND	ND
		H29. 6. 8 ~ H29. 6. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.20	ND	ND
		H29. 6. 15 ~ H29. 6. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.38	ND	ND
		H29. 6. 22 ~ H29. 6. 29	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.33	ND	ND
		H29. 6. 29 ~ H29. 7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.43	ND	ND
		H29. 7. 6 ~ H29. 7. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.43	ND	ND
		H29. 7. 13 ~ H29. 7. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.31	ND	ND
		H29. 7. 20 ~ H29. 7. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.56	ND	ND
		H29. 7. 27 ~ H29. 8. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.81	ND	ND
		H29. 8. 3 ~ H29. 8. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.91	ND	ND
		H29. 8. 10 ~ H29. 8. 17	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.99	ND	ND
		H29. 8. 17 ~ H29. 8. 24	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.81	ND	ND
		H29. 8. 24 ~ H29. 8. 31	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.41	ND	ND
		H29. 8. 31 ~ H29. 9. 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.47	ND	ND
		H29. 9. 7 ~ H29. 9. 14	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.46	ND	ND
		H29. 9. 14 ~ H29. 9. 21	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.44	ND	ND
		H29. 9. 21 ~ H29. 9. 28	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.28	ND	ND
		H29. 9. 28 ~ H29. 10. 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.27	ND	ND
		H29. 10. 5 ~ H29. 10. 12	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.35	ND	ND
		H29. 10. 12 ~ H29. 10. 19	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.36	ND	ND
		H29. 10. 19 ~ H29. 10. 26	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.53	ND	ND
		H29. 10. 26 ~ H29. 11. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.41	ND	ND
		H29. 11. 2 ~ H29. 11. 9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.34	ND	ND
		H29. 11. 9 ~ H29. 11. 16	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.26	ND	ND
		H29. 11. 16 ~ H29. 11. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 22 ~ H29. 11. 30	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.23	ND	ND

34 大熊町
南台
(ダストサンプラー)

No.	地点名	採取期間	核種濃度 (mBq/m ³)													
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce			
		H29. 11. 30 ~ H29. 12. 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 12. 7 ~ H29. 12. 14	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.33	ND
		H29. 12. 14 ~ H29. 12. 21	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.35	ND
		H29. 12. 21 ~ H29. 12. 28	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.42	ND
		H29. 12. 28 ~ H30. 1. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30. 1. 4 ~ H30. 1. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.19	ND
		H30. 1. 11 ~ H30. 1. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.37	ND
		H30. 1. 18 ~ H30. 1. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30. 1. 25 ~ H30. 2. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.39	ND

No.	地点名	採取期間	核種濃度 (mBq/m ³)														
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce				
		H29. 3. 31 ~ H29. 4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 6 ~ H29. 4. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 13 ~ H29. 4. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 20 ~ H29. 4. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 27 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 2 ~ H29. 5. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.18	ND	ND
		H29. 5. 11 ~ H29. 5. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 18 ~ H29. 5. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 25 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.27	ND	ND
		H29. 6. 1 ~ H29. 6. 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 8 ~ H29. 6. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 15 ~ H29. 6. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 22 ~ H29. 6. 29	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 29 ~ H29. 7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 6 ~ H29. 7. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 13 ~ H29. 7. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.21	ND	ND
		H29. 7. 20 ~ H29. 7. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 27 ~ H29. 8. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 3 ~ H29. 8. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 10 ~ H29. 8. 17	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 17 ~ H29. 8. 24	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.27	ND	ND
		H29. 8. 24 ~ H29. 8. 31	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 31 ~ H29. 9. 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 7 ~ H29. 9. 14	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 14 ~ H29. 9. 21	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 21 ~ H29. 9. 28	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 28 ~ H29. 10. 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 5 ~ H29. 10. 12	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.18	ND	ND
		H29. 10. 12 ~ H29. 10. 19	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 19 ~ H29. 10. 26	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 26 ~ H29. 11. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 2 ~ H29. 11. 9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 9 ~ H29. 11. 16	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 16 ~ H29. 11. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 22 ~ H29. 11. 30	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

35 浪江町
浪江
(ダストサンプラー)

No.	地点名	採取期間	核種濃度 (mBq/m ³)														
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce				
		H29. 4. 1 ~ H29. 4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 6 ~ H29. 4. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 13 ~ H29. 4. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 20 ~ H29. 4. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 27 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 2 ~ H29. 5. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.030	ND	ND
		H29. 5. 11 ~ H29. 5. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 18 ~ H29. 5. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 25 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 1 ~ H29. 6. 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 8 ~ H29. 6. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 15 ~ H29. 6. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 22 ~ H29. 6. 29	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 29 ~ H29. 7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 6 ~ H29. 7. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 13 ~ H29. 7. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 20 ~ H29. 7. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 27 ~ H29. 8. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 3 ~ H29. 8. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 10 ~ H29. 8. 17	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 17 ~ H29. 8. 24	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 24 ~ H29. 8. 31	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 31 ~ H29. 9. 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 7 ~ H29. 9. 14	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 14 ~ H29. 9. 21	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 21 ~ H29. 9. 28	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 28 ~ H29. 10. 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 5 ~ H29. 10. 12	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 12 ~ H29. 10. 19	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 19 ~ H29. 10. 26	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 26 ~ H29. 11. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 2 ~ H29. 11. 9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 9 ~ H29. 11. 16	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 16 ~ H29. 11. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 22 ~ H29. 11. 30	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

滝根
(簡易型ダスト
サンプラー)

No.	地点名	採取期間	核種濃度 (mBq/m ³)														
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce				
		H29. 4. 1 ~ H29. 4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 6 ~ H29. 4. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 13 ~ H29. 4. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 20 ~ H29. 4. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.030	ND	ND
		H29. 4. 27 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 2 ~ H29. 5. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.017	ND	ND
		H29. 5. 11 ~ H29. 5. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 18 ~ H29. 5. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 25 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 1 ~ H29. 6. 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 8 ~ H29. 6. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 15 ~ H29. 6. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 22 ~ H29. 6. 29	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 29 ~ H29. 7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 6 ~ H29. 7. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 13 ~ H29. 7. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 20 ~ H29. 7. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 27 ~ H29. 8. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.037	ND	ND
		H29. 8. 3 ~ H29. 8. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 10 ~ H29. 8. 17	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 17 ~ H29. 8. 24	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 24 ~ H29. 8. 31	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 31 ~ H29. 9. 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 7 ~ H29. 9. 14	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 14 ~ H29. 9. 21	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 21 ~ H29. 9. 28	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 28 ~ H29. 10. 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 5 ~ H29. 10. 12	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.053	ND	ND
		H29. 10. 12 ~ H29. 10. 19	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 19 ~ H29. 10. 26	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 26 ~ H29. 11. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 2 ~ H29. 11. 9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 9 ~ H29. 11. 16	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 16 ~ H29. 11. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 22 ~ H29. 11. 30	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

本日の
船
引
(簡易型ダスト
サンプラー)

田村市

No.	地点名	採取期間	核種濃度 (mBq/m ³)													
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce			
		H29. 11. 30 ~ H29. 12. 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 12. 7 ~ H29. 12. 14	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 12. 14 ~ H29. 12. 21	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 12. 21 ~ H29. 12. 28	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 12. 28 ~ H30. 1. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30. 1. 4 ~ H30. 1. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30. 1. 11 ~ H30. 1. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30. 1. 18 ~ H30. 1. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30. 1. 25 ~ H30. 2. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0. 024	ND	ND

No.	地点名	採取期間	核種濃度 (mBq/m ³)														
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce				
		H29. 4. 1 ~ H29. 4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 6 ~ H29. 4. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.025	ND
		H29. 4. 13 ~ H29. 4. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 20 ~ H29. 4. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 27 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 2 ~ H29. 5. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.021	0.024	ND
		H29. 5. 11 ~ H29. 5. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.042	ND	ND
		H29. 5. 18 ~ H29. 5. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 25 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 1 ~ H29. 6. 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 8 ~ H29. 6. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 15 ~ H29. 6. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 22 ~ H29. 6. 29	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 29 ~ H29. 7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 6 ~ H29. 7. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 13 ~ H29. 7. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.025	ND	ND
		H29. 7. 20 ~ H29. 7. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 27 ~ H29. 8. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.018	ND	ND
		H29. 8. 3 ~ H29. 8. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.087	ND	ND
		H29. 8. 10 ~ H29. 8. 17	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.027	ND	ND
		H29. 8. 17 ~ H29. 8. 24	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 24 ~ H29. 8. 31	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.023	ND	ND
		H29. 8. 31 ~ H29. 9. 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 7 ~ H29. 9. 14	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 14 ~ H29. 9. 21	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 21 ~ H29. 9. 28	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 28 ~ H29. 10. 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 5 ~ H29. 10. 12	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 12 ~ H29. 10. 19	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.028	ND	ND
		H29. 10. 19 ~ H29. 10. 26	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 26 ~ H29. 11. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.053	ND	ND
		H29. 11. 2 ~ H29. 11. 9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.17	ND	ND
		H29. 11. 9 ~ H29. 11. 16	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.022	ND	ND
		H29. 11. 16 ~ H29. 11. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 22 ~ H29. 11. 30	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

田村市
がみろつし
上 移
(簡易型ダスト
サンプラー)

No.	地点名	採取期間	核種濃度 (mBq/m ³)													
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce			
		H29. 4. 1 ~ H29. 4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.018	0.078	ND
		H29. 4. 6 ~ H29. 4. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.032	ND
		H29. 4. 13 ~ H29. 4. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.065	ND
		H29. 4. 20 ~ H29. 4. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.059	ND
		H29. 4. 27 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.041	ND
		H29. 5. 2 ~ H29. 5. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.031	0.19	0.050	ND
		H29. 5. 11 ~ H29. 5. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.050	0.20	ND
		H29. 5. 18 ~ H29. 5. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.030	0.11	ND
		H29. 5. 25 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.052	ND
		H29. 6. 1 ~ H29. 6. 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.051	ND
		H29. 6. 8 ~ H29. 6. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.061	ND
		H29. 6. 15 ~ H29. 6. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.048	ND
		H29. 6. 22 ~ H29. 6. 29	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.11	ND
		H29. 6. 29 ~ H29. 7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.10	0.071	ND
		H29. 7. 6 ~ H29. 7. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.024	0.10	0.071	ND
		H29. 7. 13 ~ H29. 7. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.10	ND
		H29. 7. 20 ~ H29. 7. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.10	ND
		H29. 7. 27 ~ H29. 8. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.046	ND
		H29. 8. 3 ~ H29. 8. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.094	ND
		H29. 8. 10 ~ H29. 8. 17	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 17 ~ H29. 8. 24	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.087	ND
		H29. 8. 24 ~ H29. 8. 31	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.093	ND
		H29. 8. 31 ~ H29. 9. 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.044	ND
		H29. 9. 7 ~ H29. 9. 14	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.10	ND
		H29. 9. 14 ~ H29. 9. 21	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.079	ND
		H29. 9. 21 ~ H29. 9. 28	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.11	ND
		H29. 9. 28 ~ H29. 10. 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.047	ND
		H29. 10. 5 ~ H29. 10. 12	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.086	ND
		H29. 10. 12 ~ H29. 10. 19	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.044	ND
		H29. 10. 19 ~ H29. 10. 26	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 26 ~ H29. 11. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.034	ND
		H29. 11. 2 ~ H29. 11. 9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.029	ND
		H29. 11. 9 ~ H29. 11. 16	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.030	ND
		H29. 11. 16 ~ H29. 11. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.072	ND
		H29. 11. 22 ~ H29. 11. 30	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.030	ND

40 南相馬市
 馬場
 (簡易型ダスト
 サンプラー)

No.	地点名	採取期間	核種濃度 (mBq/m ³)																
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce						
		H29. 4. 1 ~ H29. 4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.10	ND	ND	
		H29. 4. 6 ~ H29. 4. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.035	ND	ND
		H29. 4. 13 ~ H29. 4. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.062	ND	ND
		H29. 4. 20 ~ H29. 4. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.071	ND	ND
		H29. 4. 27 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.034	ND	ND
		H29. 5. 2 ~ H29. 5. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.025	0.14	ND	ND
		H29. 5. 11 ~ H29. 5. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.038	ND	ND
		H29. 5. 18 ~ H29. 5. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.15	ND	ND
		H29. 5. 25 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.020	0.077	ND	ND
		H29. 6. 1 ~ H29. 6. 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.036	ND	ND
		H29. 6. 8 ~ H29. 6. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.051	ND	ND
		H29. 6. 15 ~ H29. 6. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.064	ND	ND
		H29. 6. 22 ~ H29. 6. 29	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.026	ND	ND
		H29. 6. 29 ~ H29. 7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.057	ND	ND
		H29. 7. 6 ~ H29. 7. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.060	ND	ND
		H29. 7. 13 ~ H29. 7. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.059	ND	ND
		H29. 7. 20 ~ H29. 7. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.073	ND	ND
		H29. 7. 27 ~ H29. 8. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.031	ND	ND
		H29. 8. 3 ~ H29. 8. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.038	ND	ND
		H29. 8. 10 ~ H29. 8. 17	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.023	ND	ND
		H29. 8. 17 ~ H29. 8. 24	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.023	0.060	ND	ND
		H29. 8. 24 ~ H29. 8. 31	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.070	ND	ND
		H29. 8. 31 ~ H29. 9. 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.026	ND	ND
		H29. 9. 7 ~ H29. 9. 14	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.053	ND	ND
		H29. 9. 14 ~ H29. 9. 21	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.060	ND	ND
		H29. 9. 21 ~ H29. 9. 28	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.073	ND	ND
		H29. 9. 28 ~ H29. 10. 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.063	ND	ND
		H29. 10. 5 ~ H29. 10. 12	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.057	ND	ND
		H29. 10. 12 ~ H29. 10. 19	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.035	ND	ND
		H29. 10. 19 ~ H29. 10. 26	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 26 ~ H29. 11. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.031	ND	ND
		H29. 11. 2 ~ H29. 11. 9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.060	ND	ND
		H29. 11. 9 ~ H29. 11. 16	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.036	ND	ND
		H29. 11. 16 ~ H29. 11. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.042	ND	ND
		H29. 11. 22 ~ H29. 11. 30	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.063	ND	ND

南相馬市
 大木戸
 (簡易型ダスト
 サンプラー)

No.	地点名	採取期間	核種濃度 (mBq/m ³)													
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce			
		H29. 11. 30 ~ H29. 12. 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 12. 7 ~ H29. 12. 14	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 12. 14 ~ H29. 12. 21	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0. 027	ND
		H29. 12. 21 ~ H29. 12. 28	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0. 050	ND
		H29. 12. 28 ~ H30. 1. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0. 030	ND
		H30. 1. 4 ~ H30. 1. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0. 046	ND
		H30. 1. 11 ~ H30. 1. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30. 1. 18 ~ H30. 1. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0. 032	ND
		H30. 1. 25 ~ H30. 2. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0. 022	ND

No.	地点名	採取期間	核種濃度 (mBq/m ³)																		
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce								
		H29. 4. 1 ~ H29. 4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
		H29. 4. 6 ~ H29. 4. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 13 ~ H29. 4. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 20 ~ H29. 4. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 4. 27 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 2 ~ H29. 5. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 11 ~ H29. 5. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 18 ~ H29. 5. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 25 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 1 ~ H29. 6. 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 8 ~ H29. 6. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 15 ~ H29. 6. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 22 ~ H29. 6. 29	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 29 ~ H29. 7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 6 ~ H29. 7. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 13 ~ H29. 7. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 20 ~ H29. 7. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 27 ~ H29. 8. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 3 ~ H29. 8. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 10 ~ H29. 8. 17	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 17 ~ H29. 8. 24	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 24 ~ H29. 8. 31	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 31 ~ H29. 9. 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 7 ~ H29. 9. 14	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 14 ~ H29. 9. 21	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 21 ~ H29. 9. 28	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 9. 28 ~ H29. 10. 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 5 ~ H29. 10. 12	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 12 ~ H29. 10. 19	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 19 ~ H29. 10. 26	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 10. 26 ~ H29. 11. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 2 ~ H29. 11. 9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 9 ~ H29. 11. 16	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 16 ~ H29. 11. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 11. 22 ~ H29. 11. 30	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

南相馬市
じまはら 槽原
(簡易型ダスト
サンプラー) *2

No.	地点名	採取期間	核種濃度 (mBq/m ³)													
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce			
		H29. 11. 30 ~ H29. 12. 7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 12. 7 ~ H29. 12. 14	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 12. 14 ~ H29. 12. 21	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 12. 21 ~ H29. 12. 28	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0. 051	ND
		H29. 12. 28 ~ H30. 1. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0. 034	0. 028	ND
		H30. 1. 4 ~ H30. 1. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0. 024	0. 020	ND
		H30. 1. 11 ~ H30. 1. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0. 025	0. 020	ND
		H30. 1. 18 ~ H30. 1. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0. 025	0. 020	ND
		H30. 1. 25 ~ H30. 2. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0. 025	0. 025	ND

(注) 1 No. の網掛け部分は東京電力株式会社福島第一原子力発電所から半径5km未満の地域

2 「ND」：検出限界未満

3 上記の他、人工放射性核種は検出されなかった。

4 ¹³⁴Cs及び¹³⁷Csの検出限界値：連続ダストモニタはおおむね0. 01 mBq/m³以下、リアルタイムダストモニタはおおむね0. 06 mBq/m³以下、ダストサンプラー（1週間集じん）はおおむね0. 04 mBq/m³以下、簡易型ダストサンプラー（1日集じん）はおおむね0. 05 mBq/m³以下である。

5 *1 No. 31上郡山の採取期間H29. 11. 16~H29. 11. 20の測定については、ダストサンプラーの意図せぬ停止により、採取期間が短くなっている。

6 *2 No. 42糟原の採取期間H29. 7. 20~H29. 7. 22の測定については、簡易型ダストサンプラーの意図せぬ停止により、採取期間が短くなっている。

No.	地点名	採取期間	核種濃度 (Bq/m ² (MBq/km ²))												
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce		
5	双葉町 郡山	H29. 4. 3 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	69	460	ND
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	20	140	ND
		H29. 6. 1 ~ H29. 7. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	21	150	ND
		H29. 7. 3 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	16	120	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	6.4	46	ND
		H29. 9. 1 ~ H29.10. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	28	220	ND
		H29.10. 3 ~ H29.11. 1 ^{*1}	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	2.5	19	ND
		H29.11. 1 ~ H29.12. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	21	190	ND
		H29.12. 4 ~ H30. 1. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	7.4	58	ND
		H30. 1. 4 ~ H30. 2. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	7.6	65	ND
6	南相馬市 亶浜	H29. 4. 4 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.2	22	ND
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.8	12	ND
		H29. 6. 1 ~ H29. 7. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.45	2.8	ND
		H29. 7. 3 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	2.1	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.1	ND
		H29. 9. 1 ~ H29.10. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	2.8	ND
		H29.10. 3 ~ H29.11. 1 ^{*1}	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.2	10	ND
		H29.11. 1 ~ H29.12. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.3	ND
		H29.12. 4 ~ H30. 1. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.88	8.3	ND
		H30. 1. 4 ~ H30. 2. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.71	4.9	ND
7	浪江町 浪江	H29. 4. 4 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	16	110	ND
		H29. 5. 2 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.8	35	ND
		H29. 6. 1 ~ H29. 7. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.3	10	ND
		H29. 7. 3 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.3	9.5	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.48	3.8	ND
		H29. 9. 1 ~ H29.10. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	2.1	17	ND
		H29.10. 2 ~ H29.11. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.89	7.1	ND
		H29.11. 1 ~ H29.12. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.4	29	ND
		H29.12. 1 ~ H30. 1. 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	2.9	25	ND
		H30. 1. 5 ~ H30. 2. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.1	8.9	ND
8	浪江町 津島	H29. 4. 3 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	13	80	ND
		H29. 5. 2 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	8.6	58	ND
		H29. 6. 1 ~ H29. 7. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	9.7	68	ND
		H29. 7. 3 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	5.2	36	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	12	92	ND
		H29. 9. 1 ~ H29.10. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	2.8	22	ND
		H29.10. 2 ~ H29.11. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	9.9	76	ND
		H29.11. 1 ~ H29.12. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	21	160	ND
		H29.12. 1 ~ H30. 1. 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	9.3	74	ND
		H30. 1. 5 ~ H30. 2. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	7.0	59	ND

No.	地点名	採取期間	核種濃度 (Bq/m ² (MBq/km ²))												
			⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³³ Cs	¹³⁷ Cs	¹⁴⁴ Ce		
9	葛尾村 相原 <small>かしのぼり</small>	H29. 4. 4 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	9.2	60	ND
		H29. 5. 2 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	9.7	68	ND
		H29. 6. 1 ~ H29. 7. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.7	13	ND
		H29. 7. 3 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.0	21	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.4	9.6	ND
		H29. 9. 1 ~ H29.10. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	2.6	19	ND
		H29.10. 2 ~ H29.11. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.7	37	ND
		H29.11. 1 ~ H29.12. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	5.8	45	ND
		H29.12. 1 ~ H30. 1. 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	7.1	57	ND
		H30. 1. 5 ~ H30. 2. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	20	160	ND
10	川俣町 山木屋 <small>やまぎ</small>	H29. 4. 3 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	10	65	ND
		H29. 5. 2 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	11	72	ND
		H29. 6. 1 ~ H29. 7. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	9.6	64	ND
		H29. 7. 3 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	7.1	49	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.8	29	ND
		H29. 9. 1 ~ H29.10. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.2	25	ND
		H29.10. 2 ~ H29.11. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	2.0	15	ND
		H29.11. 1 ~ H29.12. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	2.4	18	ND
		H29.12. 1 ~ H30. 1. 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.2	26	ND
		H30. 1. 5 ~ H30. 2. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.6	28	ND

(注) 1 No.の縦掛け部分は東京電力株式会社福島第一原子力発電所から半径5km未満の地域

2 「ND」：検出限界未満

3 *1 試料採取期間中、試料採取容器から試料があふれたため、参考値とする。

試料名	種類 又は 部位	採取 年月日	採取地点番号 及び採取地点名	単位	全γ- 放射能 測定値	核種濃度														天然 核種																						
						⁶ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁶ Zr	⁹³ Nb	¹⁰¹ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴¹ Ce	³ H	¹³¹ I	⁸⁷ Sr		⁹⁰ Sr	^{239,240} Pu	²⁴¹ Am	²⁴⁴ Cm																		
海水	表面水	7	第二(案)南放水口	Bq/l	0.01	⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	0.003	¹³⁷ Cs	0.024	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	0.0013	^{239,240} Pu	ND	²⁴¹ Am	ND	²⁴⁴ Cm	ND	490
						⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	0.004	¹³⁷ Cs	0.031	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	ND	^{239,240} Pu	ND	²⁴¹ Am	ND	²⁴⁴ Cm	ND	490
						⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	0.003	¹³⁷ Cs	0.017	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	ND	^{239,240} Pu	ND	²⁴¹ Am	ND	²⁴⁴ Cm	ND	490
						⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	ND	¹³⁷ Cs	0.018	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	0.0011	^{239,240} Pu	ND	²⁴¹ Am	ND	²⁴⁴ Cm	ND	490
						⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	0.005	¹³⁷ Cs	0.037	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	ND	^{239,240} Pu	ND	²⁴¹ Am	ND	²⁴⁴ Cm	ND	490
						⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	0.003	¹³⁷ Cs	0.029	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	ND	^{239,240} Pu	ND	²⁴¹ Am	ND	²⁴⁴ Cm	ND	490
						⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	52	¹³⁷ Cs	360	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	0.23	^{239,240} Pu	ND	²⁴¹ Am	0.20	²⁴⁴ Cm	ND	510
						⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	42	¹³⁷ Cs	300	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	ND	^{239,240} Pu	ND	²⁴¹ Am	0.21	²⁴⁴ Cm	ND	500
海底土	海底土	1	第一(案)南放水口付近*3	Bq/kg乾	ND	⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	34	¹³⁷ Cs	280	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	0.38	^{239,240} Pu	ND	²⁴¹ Am	0.18	²⁴⁴ Cm	ND	490
						⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	26	¹³⁷ Cs	180	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	ND	^{239,240} Pu	ND	²⁴¹ Am	0.29	²⁴⁴ Cm	ND	460
						⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	19	¹³⁷ Cs	140	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	ND	^{239,240} Pu	ND	²⁴¹ Am	0.30	²⁴⁴ Cm	ND	490
						⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	22	¹³⁷ Cs	180	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	0.20	^{239,240} Pu	ND	²⁴¹ Am	0.32	²⁴⁴ Cm	ND	500
						⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	52	¹³⁷ Cs	360	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	ND	^{239,240} Pu	ND	²⁴¹ Am	0.26	²⁴⁴ Cm	ND	520
						⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	38	¹³⁷ Cs	280	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	ND	^{239,240} Pu	ND	²⁴¹ Am	0.25	²⁴⁴ Cm	ND	500
						⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	35	¹³⁷ Cs	280	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	0.77	^{239,240} Pu	ND	²⁴¹ Am	0.41	²⁴⁴ Cm	ND	540
						⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	23	¹³⁷ Cs	150	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	ND	^{239,240} Pu	ND	²⁴¹ Am	0.33	²⁴⁴ Cm	ND	450
						⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	11	¹³⁷ Cs	78	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	ND	^{239,240} Pu	ND	²⁴¹ Am	0.40	²⁴⁴ Cm	ND	450
						⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	6.2	¹³⁷ Cs	52	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	0.71	^{239,240} Pu	ND	²⁴¹ Am	0.32	²⁴⁴ Cm	ND	450
						⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	6.9	¹³⁷ Cs	48	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	ND	^{239,240} Pu	ND	²⁴¹ Am	0.42	²⁴⁴ Cm	ND	480
						⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	5.9	¹³⁷ Cs	45	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	0.39	^{239,240} Pu	ND	²⁴¹ Am	0.41	²⁴⁴ Cm	ND	490
						⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	6.7	¹³⁷ Cs	52	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	0.29	^{239,240} Pu	0.01	²⁴¹ Am	0.41	²⁴⁴ Cm	ND	490
						⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	10	¹³⁷ Cs	72	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	ND	^{239,240} Pu	ND	²⁴¹ Am	0.47	²⁴⁴ Cm	ND	490
						⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	5.1	¹³⁷ Cs	39	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	ND	^{239,240} Pu	ND	²⁴¹ Am	0.42	²⁴⁴ Cm	ND	470
						⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	5.7	¹³⁷ Cs	48	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	0.30	^{239,240} Pu	ND	²⁴¹ Am	0.61	²⁴⁴ Cm	ND	490
⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	15	¹³⁷ Cs	100	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	0.32	^{239,240} Pu	ND	²⁴¹ Am	0.24	²⁴⁴ Cm	ND	490						
⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	15	¹³⁷ Cs	120	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	ND	^{239,240} Pu	ND	²⁴¹ Am	ND	²⁴⁴ Cm	ND	480						
⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	14	¹³⁷ Cs	120	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	ND	^{239,240} Pu	ND	²⁴¹ Am	ND	²⁴⁴ Cm	ND	540						
⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	12	¹³⁷ Cs	83	¹⁴¹ Ce	ND	³ H	ND	¹³¹ I	ND	⁸⁷ Sr	ND	⁹⁰ Sr	0.18	^{239,240} Pu	ND	²⁴¹ Am	0.22	²⁴⁴ Cm	ND	520						
⁶ Cr	ND	⁵⁴ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	7.4	¹³⁷ Cs	56																							

試料名	種類 又は 部位	採取 年月日	採取地点番号 及び採取地点名	単位	全γ線 放射能 測定値	核種濃度														天然 核種																									
						⁶⁰ Cr	⁵¹ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁶ Zr	⁹³ Nb	¹⁰¹ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴¹ Ce	³ H	¹³¹ I	⁸⁷ Sr		⁹⁰ Sr	²³² Pu	²³⁸ U	²⁴¹ Am	²⁴⁴ Cm																				
松 葉 二年葉	種類 又は 部位	E29. 6. 12 E29. 8. 24 E29. 11. 7 E29. 6. 12 E29. 8. 24 E29. 11. 28 E29. 6. 12 E29. 8. 24 E29. 11. 7 E29. 6. 13 E29. 8. 24 E29. 11. 7 E29. 6. 13 E29. 9. 4 E29. 11. 7 E29. 6. 12 E29. 8. 24 E29. 11. 28 E29. 6. 7 E29. 9. 7 E29. 11. 20 E29. 6. 7 E29. 9. 7 E29. 11. 20 E29. 6. 7 E29. 9. 13 E29. 11. 20 E29. 6. 5 E29. 9. 4 E29. 11. 9	1 いわき市 久志 2 田村市 古道 3 広野町 上北道 4 楢葉町 波倉 5 富岡町 小浜 6 川内村 上川内 7 大熊町 天沢 8 大熊町 天川原 9 双葉町 郡山 10 浪江町 北幾世橋	Bq/kg生	/	⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	0.72	¹³⁷ Cs	3.8	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	58
						⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	1.0	¹³⁷ Cs	5.0	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	60
						⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	3.1	¹³⁷ Cs	3.1	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	81
						⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	1.6	¹³⁷ Cs	1.6	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	84
						⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	2.1	¹³⁷ Cs	2.1	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	78
						⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	2.7	¹³⁷ Cs	2.7	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	90
						⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	3.0	¹³⁷ Cs	3.0	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	79
						⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	0.74	¹³⁷ Cs	5.9	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	52
						⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	12	¹³⁷ Cs	89	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	86
						⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	17	¹³⁷ Cs	130	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	78
⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	11	¹³⁷ Cs	84	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	40						
⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	16	¹³⁷ Cs	110	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	52						
⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	9.1	¹³⁷ Cs	67	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	49						
⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	13	¹³⁷ Cs	110	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	45						
⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	ND	¹³⁷ Cs	0.88	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	73						
⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	ND	¹³⁷ Cs	1.7	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	66						
⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	ND	¹³⁷ Cs	1.3	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	64						
⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	74	¹³⁷ Cs	530	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	74						
⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	39	¹³⁷ Cs	300	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	64						
⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	92	¹³⁷ Cs	750	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	50						
⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	16	¹³⁷ Cs	110	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	58						
⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	8.8	¹³⁷ Cs	70	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	51						
⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	21	¹³⁷ Cs	170	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	63						
⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	25	¹³⁷ Cs	190	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	88						
⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	21	¹³⁷ Cs	160	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	49						
⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	37	¹³⁷ Cs	320	¹⁴¹ Ce	ND	³ H	/	¹³¹ I	ND	⁸⁷ Sr	/	⁹⁰ Sr	/	²³² Pu	/	²³⁸ U	/	²⁴¹ Am	/	²⁴⁴ Cm	/	⁹⁰ K	40						
⁶⁰ Cr	ND	⁵¹ Mn	ND	⁵⁸ Co	ND	⁵⁹ Fe	ND	⁶⁰ Co	ND	⁹⁶ Zr	ND	⁹³ Nb	ND	¹⁰¹ Ru	ND	¹³⁴ Cs	2.2	¹³⁷ Cs	16	¹⁴¹																									

5-3 比較対照地点

5-3-1 空間線量率(比較対照地点)

単位:線量率:μGy/h、測定時間:h
上段:平均値(下段):最大値

No.	測定地点名	測定年月		H29.4		5		6		7		8		9		10		11		12		H30.1		2		3				
		測定項目	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間		
1	福島市 福島市 紅葉山 (高さ2.5mの測定値)	福島市 福島市 紅葉山 (高さ2.5mの測定値)	119 (130)	720	119 (127)	744	118 (131)	720	116 (142)	744	112 (126)	744	113 (131)	720	111 (123)	736	111	720	110 (124)	720	111	744	107 (146)	744						
		福島市 福島市 紅葉山 (高さ1mの測定値)	128 (137)	720	129 (141)	744	129 (141)	720	127 (150)	744	120 (131)	744	122 (135)	720	120 (130)	736	119	744	120 (133)	720	119	744	114 (159)	744						
2	郡山市 ひがし和田	142 (159)	720	143 (157)	744	143 (163)	720	141 (168)	744	137 (156)	744	137 (156)	715	136 (157)	744	134 (159)	744	136 (155)	718	134 (159)	744	128 (173)	744							
3	いわき市	65 (75)	720	65 (80)	744	64 (73)	720	65 (84)	744	64 (77)	744	65 (83)	715	63 (81)	744	65 (79)	738	64 (75)	716	65 (79)	738	64 (82)	744							

No.	地点名	採取期間	核種濃度 (mBq/m ³)														
			⁵¹ Cr	⁵⁵ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁵ Zr	⁹⁵ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce				
5	相馬市 <small>まが</small> 野 主 (簡易型ダスト サンプル)	H29.4.4 ~ H29.4.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
		H29.5.10 ~ H29.5.11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.034	ND	ND	
		H29.6.14 ~ H29.6.15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.7.4 ~ H29.7.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.8.1 ~ H29.8.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.9.13 ~ H29.9.14	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.10.10 ~ H29.10.11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.036	ND	ND
		H29.11.6 ~ H29.11.7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.12.6 ~ H29.12.7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.1.11 ~ H30.1.12	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.035	ND	ND
6	伊達市 <small>い</small> 成 富 (簡易型ダスト サンプル)	H29.4.4 ~ H29.4.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.5.10 ~ H29.5.11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.041	ND	ND
		H29.6.14 ~ H29.6.15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.7.4 ~ H29.7.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.8.1 ~ H29.8.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.039	ND	ND
		H29.9.13 ~ H29.9.14	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.10.10 ~ H29.10.11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.048	ND	ND
		H29.11.6 ~ H29.11.7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.030	ND	ND
		H29.12.6 ~ H29.12.7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.1.11 ~ H30.1.12	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
7	南会津町 <small>な</small> 島 田 (簡易型ダスト サンプル)	H29.4.11 ~ H29.4.12	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.5.1 ~ H29.5.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.6.6 ~ H29.6.7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.051	ND	ND
		H29.7.6 ~ H29.7.7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.8.3 ~ H29.8.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.9.7 ~ H29.9.8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.10.3 ~ H29.10.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.11.1 ~ H29.11.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.12.4 ~ H29.12.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H30.1.9 ~ H30.1.10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

(注) 1 「ND」：検出限界未満「—」：欠測
2 上記の他、人工放射性核種は検出されなかった。
3 ろ紙の灰化処理はせず、ろ紙を直接α8容器で測定した。
4 ¹³⁴Cs及び¹³⁷Csの検出限界値：簡易型ダストサンプル（1週間集じん）はおおむね0.04 mBq/m3以下である。

5-3-3 大気中水分のトリチウム濃度 (比較対照地点)

No.	地点名	採取期間	トリチウム濃度		備考
			大気中濃度 (mBq/m ³)	(参考値) 捕集水濃度 (Bq/l)	
1	福島市 方木 ^{ほうき} 田	H29. 4. 3 ~ H29. 5. 1	6. 0	0. 98	大気中水分量 (g /m ³) 6. 1
		H29. 5. 1 ~ H29. 6. 1	6. 2	0. 61	10
		H29. 6. 1 ~ H29. 7. 3	14	1. 0	13
		H29. 7. 3 ~ H29. 8. 1	18	0. 91	20
		H29. 8. 1 ~ H29. 9. 1	ND	ND	18
		H29. 9. 1 ~ H29. 10. 2	6. 4	0. 49	13
		H29. 10. 2 ~ H29. 11. 1	ND	ND	10
		H29. 11. 1 ~ H29. 12. 1	ND	ND	5. 9
		H30. 12. 1 ~ H30. 1. 4 [※]	—	—	—
		H30. 1. 4 ~ H30. 2. 1	ND	ND	3. 6

(注) 「ND」：検出限界未満

「※」：平成29年12月1日～平成30年1月4日採取分については、試料損失の可能性があるため欠測

5-3-4 降下物の核種濃度（比較対照地点）

No.	地点名	採取期間	⁵¹ Cr	⁵⁴ Mn	⁵⁸ Co	⁵⁹ Fe	⁶⁰ Co	⁹⁶ Zr	⁹⁶ Nb	¹⁰⁶ Ru	¹³⁴ Cs	¹³⁷ Cs	¹⁴⁴ Ce	
1	福島市 <small>ふくしま</small> 方田	H29. 4. 3 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	6.9	45	ND	
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.8	26	ND
		H29. 6. 1 ~ H29. 7. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.1	8.0	ND
		H29. 7. 3 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.46	3.1	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.19	1.4	ND
		H29. 9. 1 ~ H29.10. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.27	2.1	ND
		H29.10. 2 ~ H29.11. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.29	2.0	ND
		H29.11. 1 ~ H29.12. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.80	6.3	ND
		H29.12. 1 ~ H30. 1. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.9	15	ND
		H30. 1. 4 ~ H30. 2. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.1	26	ND
		H29. 4. 3 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.88	ND
H29. 6. 1 ~ H29. 7. 3 *1	-	-	-	-	-	-	-	-	-	-	-	-		
H29. 7. 3 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.33	ND		
H29. 9. 1 ~ H29.10. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.44	ND		
H29.10. 2 ~ H29.11. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.70	3.2	ND	
H29.11. 1 ~ H29.12. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
H29.12. 1 ~ H30. 1. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.1	ND	
H30. 1. 4 ~ H30. 2. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	2.0	ND	

(注) 1 「ND」：検出限界未満 「/」：対象外核種

2 上記の他、人工放射性核種は検出されなかった。

3 *1 前処理中に、試料の損失があったため、欠測とする。残試料の測定において、Cs-134はND、Cs-137は1.5Bq/m2であった。

5-4 試料採取時の付帯データ集
 (原子力発電所周辺等環境放射能測定)

1 上水

No.	採取地点名	採取年月日	気温 (℃)	水温 (℃)	pH
1	いわき市	H29. 4. 17	18.5	12.0	7.8
		H29. 7. 4	26.1	23.0	7.8
		H29. 10. 3	27.2	22.0	7.6
		H30. 1. 5	7.8	7.5	7.5
2	田村市	H29. 4. 7	14.9	9.5	7.6
		H29. 7. 4	21.8	22.5	7.7
		H29. 10. 3	23.8	24.0	7.7
		H30. 1. 5	2.5	5.5	7.2
3	広野町	H29. 4. 7	20.5	11.0	7.9
		H29. 7. 5	30.2	24.0	8.1
		H29. 10. 4	22.2	20.0	7.6
		H30. 1. 12	10.4	6.5	7.9
4	檜葉町	H29. 4. 7	16.5	12.0	7.9
		H29. 7. 5	26.1	24.3	8.0
		H29. 10. 4	27.8	21.0	7.8
		H30. 1. 12	4.1	6.0	7.8
5	富岡町	H29. 4. 17	15.3	14.2	7.8
		H29. 7. 5	28.6	22.8	7.8
		H29. 10. 4	30.0	20.0	7.6
		H30. 1. 12	5.0	9.2	7.5
6	川内村	H29. 4. 7	16.3	14.5	8.0
		H29. 7. 4	23.6	18.6	8.0
		H29. 10. 3	25.2	20.0	7.8
		H30. 1. 10	5.0	8.5	7.8
7	大熊町	—	—	—	—
		—	—	—	—
		—	—	—	—
		—	—	—	—
8	双葉町	—	—	—	—
		—	—	—	—
		—	—	—	—
		—	—	—	—
9	浪江町	H29. 4. 6	21.0	14.0	7.8
		H29. 7. 5	29.1	26.0	7.7
		H29. 10. 4	30.6	21.5	7.6
		H30. 1. 12	4.5	7.9	7.4
10	葛尾村	H29. 4. 7	16.6	14.3	7.8
		H29. 7. 6	27.5	21.8	7.9
		H29. 10. 5	16.8	18.5	7.8
		H30. 1. 10	5.2	6.5	7.5
11	南相馬市	H29. 4. 6	16.8	13.5	7.7
		H29. 7. 5	24.3	24.5	7.5
		H29. 10. 4	29.7	22.0	7.6
		H30. 1. 12	4.4	12.0	7.1
12	飯館村	H29. 4. 20	17.8	12.0	8.0
		H29. 7. 6	27.1	22.8	8.0
		H29. 10. 5	15.0	19.0	7.9
		H30. 1. 10	2.4	3.0	7.8
13	川俣町	H29. 4. 7	18.5	13.5	7.9
		H29. 7. 6	26.3	23.0	7.9
		H29. 10. 26	27.8	13.5	7.8
		H30. 1. 10	5.0	2.1	7.5

2 海水

No.	採取地点名	採取年月日	気温 (°C)	水温 (°C)	p H	C ℓ ⁻ (‰)
1	第一(発)南放水口付近	H29. 4. 20	13.3	9.4	8.2	19
		H29. 5. 16	15.0	14.1	8.2	18
		H29. 6. 13	15.0	14.8	8.2	17
		H29. 7. 10	20.0	19.8	8.1	18
		H29. 8. 18	24.0	24.0	8.2	16
		H29. 9. 14	22.0	21.7	8.1	18
		H29.10.17	15.0	17.9	8.1	19
		H29.11.14	14.0	15.1	8.3	20
		H29.12. 5	10.5	11.9	8.1	18
2	第一(発)北放水口付近	H30. 1. 16	7.5	7.3	8.2	19
		H29. 4. 20	13.0	9.6	8.2	18
		H29. 5. 16	14.0	13.9	8.2	18
		H29. 6. 13	14.9	15.0	8.2	18
		H29. 7. 10	20.0	19.2	8.1	18
		H29. 8. 18	24.0	23.4	8.2	16
		H29. 9. 14	22.0	21.7	8.1	18
		H29.10.17	15.0	17.7	8.1	18
		H29.11.14	14.0	15.2	8.3	18
3	第一(発)取水口付近 (港湾出入口の外側)	H29.12. 5	10.5	11.5	8.1	18
		H29. 4. 20	13.0	9.8	8.2	19
		H29. 5. 16	14.5	14.2	8.2	18
		H29. 6. 13	14.4	14.7	8.2	18
		H29. 7. 10	20.0	18.6	8.1	18
		H29. 8. 18	24.0	23.4	8.2	16
		H29. 9. 14	22.0	21.8	8.1	18
		H29.10.17	15.0	17.1	8.1	18
		H29.11.14	14.0	15.1	8.4	17
4	第一(発)沖合 2 km	H29.12. 5	11.5	11.6	8.1	17
		H30. 1. 16	7.0	7.4	8.1	19
		H29. 4. 20	11.1	9.4	8.2	18
		H29. 5. 16	14.0	13.8	8.2	18
		H29. 6. 13	14.2	14.9	8.2	18
		H29. 7. 10	21.0	19.4	8.1	18
		H29. 8. 18	23.0	23.3	8.2	16
		H29. 9. 14	22.0	21.7	8.1	18
		H29.10.17	15.0	17.8	8.1	18
5	夫沢・熊川沖 2 km	H29.11.14	14.0	15.1	8.4	19
		H29.12. 5	9.5	11.3	8.1	18
		H30. 1. 16	6.5	7.7	8.1	18
		H29. 4. 20	11.0	9.6	8.2	19
		H29. 5. 16	14.0	13.6	8.2	17
		H29. 6. 13	14.7	14.8	8.1	18
		H29. 7. 10	21.0	20.1	8.1	18
		H29. 8. 18	23.0	23.5	8.2	16
		H29. 9. 14	23.5	21.3	8.1	18
6	双葉・前田川沖 2 km	H29.10.17	14.0	17.6	8.1	18
		H29.11.14	14.0	15.1	8.3	18
		H29.12. 5	10.0	11.6	8.1	18
		H30. 1. 16	7.0	7.2	8.0	18
		H29. 4. 20	11.1	9.7	8.2	18
		H29. 5. 16	13.8	13.8	8.2	18
		H29. 6. 13	15.0	15.4	8.2	18
		H29. 7. 10	21.0	19.3	8.1	18
		H29. 8. 18	23.0	23.3	8.2	16
7	第二(発)南放水口	H29. 9. 14	22.0	21.8	8.2	18
		H29.10.17	14.5	17.5	8.1	18
		H29.11.14	14.0	15.1	8.4	18
		H29.12. 5	10.0	11.8	8.1	18
8	第二(発)北放水口	H30. 1. 16	6.5	7.5	8.1	18
		H29. 5. 10	15.5	12.0	8.1	19
		H29. 8. 21	27.4	24.0	7.7	17
		H29.11. 8	16.2	16.6	7.5	18

(比較対照地点環境放射能測定)

1 上水

No.	採取地点名	採取年月日	気温 (°C)	水温 (°C)	p H
1	福島市	H29. 4. 14	19. 8	8. 3	7. 4
2	会津若松市	H29. 4. 11	10. 0	11. 5	7. 2

2 海水

No.	採取地点名	採取年月日	気温 (°C)	水温 (°C)	p H	Cl ⁻ (‰)
1	相馬市松川浦沖	H29. 9. 27	24. 5	23. 0	8. 1	18