

初野浄水場 流量水質報告書

令和4年4月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカリ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	36,260	3.20	7.47	—	19,790	14,930	2.35	7.54	7.50	0.00	0.00	
2	36,770	3.22	7.45	—	19,370	15,620	2.31	7.56	7.70	0.00	0.00	
3	35,460	3.18	7.47	—	18,160	14,510	2.32	7.54	7.30	0.00	0.00	
4	35,220	3.19	7.50	—	18,340	14,280	2.19	7.63	7.60	0.00	0.00	
5	35,590	3.20	7.45	—	18,080	15,430	2.04	7.58	7.60	0.00	0.00	
6	36,540	3.29	7.47	—	17,940	15,330	2.06	7.60	7.90	0.00	0.00	
7	33,610	2.00	7.52	—	16,090	14,140	1.32	7.46	8.10	0.00	0.00	
8	36,180	2.01	7.52	—	19,650	15,720	1.34	7.52	7.80	0.00	0.00	
9	36,460	2.21	7.53	—	21,970	17,150	1.51	7.45	8.50	0.00	0.00	
10	37,840	2.08	7.51	—	23,090	18,710	1.40	7.45	9.00	0.00	0.00	
11	37,980	2.12	7.52	—	23,420	18,570	1.39	7.42	9.10	0.00	0.00	
12	36,720	2.16	7.52	—	22,330	18,490	1.41	7.49	9.70	0.00	0.00	
13	38,670	2.20	7.51	—	23,990	19,730	1.45	7.45	10.30	0.00	0.00	
14	37,120	2.25	7.59	—	23,020	18,570	1.45	7.46	9.20	0.00	0.00	
15	40,070	2.16	7.52	—	25,300	19,230	1.44	7.48	9.70	0.00	0.00	
16	36,600	2.23	7.51	—	23,380	18,230	1.44	7.46	9.30	0.00	0.00	
17	36,210	2.11	7.55	—	23,030	18,140	1.40	7.43	9.30	0.00	0.00	
18	36,090	2.07	7.57	—	22,640	17,890	1.38	7.44	9.60	0.00	0.00	
19	37,500	2.04	7.54	—	23,010	19,600	1.32	7.41	10.30	0.00	0.00	
20	34,650	2.06	7.56	—	21,160	17,960	1.35	7.51	10.00	0.00	0.00	
21	36,460	2.12	7.55	—	22,000	18,740	1.40	7.48	10.40	0.00	0.00	
22	37,310	2.05	7.54	—	23,080	19,390	1.43	7.48	10.90	0.00	0.00	
23	36,460	2.03	7.50	—	22,990	18,550	1.30	7.43	11.50	0.00	0.00	
24	36,860	1.98	7.53	—	23,490	17,960	1.29	7.51	11.90	0.00	0.00	
25	37,450	2.03	7.56	—	23,890	17,550	1.34	7.42	11.70	0.00	0.00	
26	33,720	1.91	7.56	—	19,730	15,160	1.24	7.51	12.10	0.00	0.00	
27	31,680	1.96	7.57	—	18,500	14,460	1.20	7.42	12.50	0.00	0.00	
28	32,440			—	19,070	15,080				0.00	0.00	
29	34,450	1.26	7.57	—	20,370	15,120	0.75	7.52	12.50	0.00	0.00	
30	37,570	1.61	7.55	—	24,390	17,890	0.87	7.51	11.90	0.00	0.00	
合計	1,085,940			—	641,270	512,130				0.00	0.00	
最大	40,070	3.29	7.59	—	25,300	19,730	2.35	7.63	12.50	0.00	0.00	
最小	31,680	1.26	7.45	—	16,090	14,140	0.75	7.41	7.30	0.00	0.00	
平均	36,198	2.27	7.52	—	21,376	17,071	1.51	7.49	9.69	0.00	0.00	

初野浄水場 流量水質報告書

令和4年5月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカリ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	38,050	1.47	7.58	—	24,670	18,240	0.87	7.53	12.10	0.00	0.00	
2	37,150	1.60	7.52	—	24,390	17,950	0.98	7.56	11.90	0.00	0.00	
3	36,080	1.52	7.59	—	23,090	18,340	0.97	7.53	12.00	0.00	0.00	
4	36,300	1.55	7.58	—	23,000	18,710	0.95	7.50	13.00	0.00	0.00	
5	35,870	1.60	7.60	—	22,120	18,950	1.04	7.45	12.80	0.00	0.00	
6	36,820	1.60	7.60	—	22,850	18,920	1.05	7.42	12.90	0.00	0.00	
7	35,320	1.63	7.60	—	22,160	18,280	1.06	7.42	13.10	0.00	0.00	
8	35,990	1.78	7.67	—	22,350	19,000	1.05	7.53	13.30	0.00	0.00	
9	36,680	1.86	7.57	—	23,150	19,260	1.15	7.50	13.70	0.00	0.00	
10	36,490	1.92	7.56	—	23,380	19,340	1.20	7.42	13.20	0.00	0.00	
11	36,820	1.88	7.57	—	23,450	19,620	1.20	7.43	13.10	0.00	0.00	
12	36,220	1.84	7.56	—	23,010	19,300	1.16	7.43	13.20	0.00	0.00	
13	37,850	1.75	7.53	—	24,020	20,130	1.12	7.44	13.70	0.00	0.00	
14	36,140	1.77	7.49	—	23,490	19,220	1.15	7.37	13.70	0.00	0.00	
15	36,410	2.07	7.52	—	23,700	19,490	1.36	7.49	14.50	0.00	0.00	
16	37,130	2.11	7.46	—	24,070	19,310	1.44	7.41	13.80	0.00	0.00	
17	35,380	2.19	7.44	—	23,010	18,690	1.47	7.42	13.50	0.00	0.00	
18	36,860	2.11	7.44	—	23,680	19,440	1.43	7.38	13.40	0.00	0.00	
19	36,560	2.05	7.46	—	22,660	19,390	1.46	7.42	13.60	0.00	0.00	
20	29,910	2.09	7.42	—	19,000	16,310	1.43	7.37	13.90	0.00	0.00	
21	37,980	1.34	7.39	—	23,960	20,660	0.85	7.37	14.60	0.00	0.00	
22	36,570	1.51	7.41	—	23,210	18,930	0.96	7.31	14.40	0.00	0.00	
23	37,070	1.60	7.40	—	24,400	18,820	1.00	7.28	14.30	0.00	0.00	
24	34,290	1.63	7.38	—	22,250	17,020	1.07	7.34	14.30	0.00	0.00	
25	35,740	1.76	7.36	—	21,250	16,630	1.17	7.26	14.60	0.00	0.00	
26	33,340	1.89	7.33	—	19,920	15,380	1.27	7.26	14.90	0.00	0.00	
27	34,080	2.02	7.30	—	20,670	15,570	1.43	7.23	15.10	0.00	0.00	
28	34,340	2.80	7.24	—	21,570	15,490	2.26	7.21	14.80	0.00	0.00	
29	34,070	2.48	7.26	—	20,970	15,080	1.87	7.20	14.90	0.00	0.00	
30	34,490	2.70	7.23	—	21,200	14,850	2.03	7.28	15.10	0.00	0.00	
31	34,790	3.14	7.22	—	21,690	15,620	2.52	7.15	14.60	0.00	0.00	
合計	1,110,790			—	702,340	561,940				0.00	0.00	
最大	38,050	3.14	7.67	—	24,670	20,660	2.52	7.56	15.10	0.00	0.00	
最小	29,910	1.34	7.22	—	19,000	14,850	0.85	7.15	11.90	0.00	0.00	
平均	35,832	1.91	7.46	—	22,656	18,127	1.29	7.38	13.74	0.00	0.00	

初野浄水場 流量水質報告書

令和4年6月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカリ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	32,910	3.15	7.23	—	20,660	14,770	2.62	7.26	14.70	0.00	0.00	
2	33,720	3.38	7.23	—	20,190	15,300	2.76	7.29	14.90	0.00	0.00	
3	34,410	3.43	7.22	—	20,390	15,550	2.76	7.26	14.90	0.00	0.00	
4	33,140	4.48	7.21	—	20,100	15,260	3.87	7.25	14.90	0.00	0.00	
5	33,040	3.86	7.25	—	20,000	14,410	3.31	7.26	14.90	0.00	0.00	
6	33,490	4.02	7.20	—	20,500	14,510	3.29	7.20	14.60	0.00	0.00	
7	28,590	3.20	7.18	—	17,580	12,970	2.56	7.25	14.30	0.00	0.00	
8	33,370	10.08	7.09	—	20,670	14,960	7.55	7.09	14.20	0.00	0.00	
9	33,740	10.50	7.04	—	20,500	15,080	8.73	7.03	13.80	0.00	0.00	
10	33,650	10.08	7.08	—	20,270	15,190	9.03	7.04	13.80	0.00	0.00	
11	33,160	9.90	7.08	—	20,020	15,090	8.62	7.04	13.80	0.00	0.00	
12	33,320	9.42	7.09	—	20,460	14,750	7.89	6.92	13.90	0.00	0.00	
13	33,690	8.67	7.14	—	21,100	14,580	7.52	7.03	14.10	0.00	0.00	
14	33,050	8.10	7.05	—	19,500	15,190	6.87	7.02	13.80	0.00	0.00	
15	32,440	7.66	7.11	—	19,430	15,100	6.64	6.93	13.80	0.00	0.00	
16	38,180	7.65	7.10	—	22,840	17,310	6.22	6.97	14.30	0.00	0.00	
17	27,630	7.85	7.10	—	16,260	12,980	6.81	6.92	14.20	0.00	0.00	
18	34,290	7.17	7.11	—	19,940	15,790	5.90	6.90	14.60	0.00	0.00	
19	32,890	5.71	7.15	—	19,000	14,510	4.61	6.93	14.60	0.00	0.00	
20	33,620	5.50	7.10	—	19,710	14,910	4.46	6.98	14.80	0.00	0.00	
21	32,620	5.24	7.08	—	18,980	15,260	4.31	6.91	15.00	0.00	0.00	
22	32,300	5.22	7.08	—	18,610	14,900	4.22	6.92	14.80	0.00	0.00	
23	33,290	5.16	7.10	—	18,890	15,180	4.10	7.00	14.70	0.00	0.00	
24	34,220	4.86	7.08	—	19,200	15,610	4.00	6.98	15.00	0.00	0.00	
25	33,050	4.69	7.10	—	19,480	15,470	3.95	7.08	15.20	0.00	0.00	
26	32,970	4.50	7.04	—	19,430	14,580	3.76	6.92	15.60	0.00	0.00	
27	32,980	4.36	7.02	—	19,430	14,580	3.59	7.00	15.30	0.00	0.00	
28	33,830	3.65	7.01	—	20,370	15,630	2.53	6.96	15.40	0.00	0.00	
29	33,540	3.44	7.04	—	20,300	15,390	2.58	6.96	15.50	0.00	0.00	
30	34,080	3.04	7.02	—	19,460	15,850	2.45	7.01	15.80	0.00	0.00	
合計	995,210			—	593,270	450,660				0.00	0.00	
最大	38,180	10.50	7.25	—	22,840	17,310	9.03	7.29	15.80	0.00	0.00	
最小	27,630	3.04	7.01	—	16,260	12,970	2.45	6.90	13.80	0.00	0.00	
平均	33,174	5.93	7.11	—	19,776	15,022	4.92	7.04	14.64	0.00	0.00	

初野浄水場 流量水質報告書

令和4年7月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	36,710	3.34	7.03	—	21,530	16,450	2.81	7.02	15.90	0.00	0.00	
2	34,910	3.27	7.03	—	20,010	15,470	3.72	6.97	16.00	0.00	0.00	
3	35,430	3.33	7.05	—	20,970	14,890	2.09	7.00	16.40	0.00	0.00	
4	36,110	3.36	7.02	—	22,850	14,840	2.09	7.00	16.30	0.00	0.00	
5	33,980	2.73	7.01	—	20,380	15,630	1.84	6.96	16.30	0.00	0.00	
6	33,480	2.82	6.95	—	19,030	15,670	2.06	6.94	16.20	0.00	0.00	
7	33,590	2.80	6.99	—	20,440	15,930	1.79	6.96	16.20	0.00	0.00	
8	33,750	2.84	6.99	—	20,760	15,590	1.78	7.02	16.10	0.00	0.00	
9	33,720	2.91	7.00	—	20,750	15,440	1.69	7.00	16.20	0.00	0.00	
10	33,790	2.89	7.04	—	21,250	15,050	1.69	6.98	16.20	0.00	0.00	
11	34,150	2.86	7.00	—	20,800	14,880	1.77	6.97	16.40	0.00	0.00	
12	33,510	2.85	7.01	—	20,590	15,970	1.75	6.95	16.30	0.00	0.00	
13	37,730	2.82	7.00	—	23,680	19,090	2.13	7.00	16.30	0.00	0.00	
14	37,450	3.13	6.93	—	24,690	19,480	2.16	6.89	16.00	0.00	0.00	
15	36,970	3.07	7.03	—	24,520	19,310	2.11	6.99	18.40	0.00	0.00	
16	37,640	2.42	6.98	—	25,570	19,720	2.41	6.99	18.50	0.00	0.00	
17	36,310	2.55	7.02	—	25,080	18,640	1.57	6.98	18.40	0.00	0.00	
18	35,870	2.49	7.02	—	23,710	18,890	1.55	7.01	18.70	0.00	0.00	
19	35,680	2.47	7.00	—	23,170	19,230	1.41	6.97	18.80	0.00	0.00	
20	37,250	2.34	7.02	—	24,510	20,300	1.36	6.99	18.70	0.00	0.00	
21	36,660	2.30	6.98	—	24,310	19,900	1.33	7.05	19.20	0.00	0.00	
22	36,470	2.29	7.03	—	24,280	19,860	1.34	6.97	19.00	0.00	0.00	
23	36,850	2.29	7.03	—	25,520	19,740	1.28	6.97	19.00	0.00	0.00	
24	37,490	2.20	7.03	—	25,740	19,900	1.25	7.00	19.30	0.00	0.00	
25	36,330	2.08	7.03	—	25,320	19,390	1.14	6.94	19.20	0.00	0.00	
26	36,260	2.35	6.99	—	24,810	19,230	1.12	6.97	19.40	0.00	0.00	
27	37,120	2.15	7.00	—	24,810	20,680	1.24	6.96	19.60	0.00	0.00	
28	34,330	2.49	7.00	—	23,100	19,480	1.39	6.90	19.10	0.00	0.00	
29	36,040	2.51	6.98	—	24,230	20,280	1.26	6.95	19.50	0.00	0.00	
30	35,700	2.50	6.98	—	24,290	19,580	1.19	6.94	19.50	0.00	0.00	
31	35,380	2.44	6.96	—	24,210	19,270	1.15	6.95	19.80	0.00	0.00	
合計	1,106,660			—	714,910	557,780				0.00	0.00	
最大	37,730	3.36	7.05	—	25,740	20,680	3.72	7.05	19.80	0.00	0.00	
最小	33,480	2.08	6.93	—	19,030	14,840	1.12	6.89	15.90	0.00	0.00	
平均	35,699	2.67	7.00	—	23,062	17,993	1.72	6.97	17.77	0.00	0.00	

初野浄水場 流量水質報告書

令和4年8月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	35,830	2.61	6.98	—	24,060	19,560	1.23	7.00	20.10	0.00	0.00	
2	35,160	1.80	6.88	—	23,750	19,320	1.15	6.82	16.70	0.00	0.00	
3	37,220	1.98	6.90	—	25,040	20,940	1.15	6.89	16.30	0.00	0.00	
4	34,270	1.12	6.86	—	23,350	18,870	0.44	6.87	16.10	0.00	0.00	
5	36,330	1.34	6.87	—	25,000	19,780	0.63	6.87	16.20	0.00	0.00	
6	35,650	1.44	6.92	—	24,870	19,570	0.69	6.96	16.30	0.00	0.00	
7	35,340	1.62	6.92	—	24,500	19,060	0.77	6.86	16.30	0.00	0.00	
8	35,290	1.73	6.91	—	24,000	19,160	0.77	6.90	16.50	0.00	0.00	
9	36,390	1.80	6.89	—	23,700	20,870	0.84	6.90	16.60	0.00	0.00	
10	36,320	1.90	6.88	—	23,980	20,950	0.87	6.84	16.50	0.00	0.00	
11	36,040	1.90	6.87	—	23,450	20,690	0.91	6.81	16.40	0.00	0.00	
12	36,150	1.93	6.85	—	24,350	20,330	0.94	6.86	16.60	0.00	0.00	
13	35,450	2.10	6.92	—	23,790	19,700	1.02	6.91	18.00	0.00	0.00	
14	35,820	2.21	6.91	—	24,540	19,430	1.07	6.88	17.90	0.00	0.00	
15	32,790	1.49	6.94	—	21,670	16,330	1.42	6.85	18.00	0.00	0.00	
16	36,670	1.42	6.93	—	24,970	19,380	1.10	6.90	18.20	0.00	0.00	
17	35,410	1.64	6.90	—	23,900	20,160	1.14	6.92	18.10	0.00	0.00	
18	35,350	1.69	6.92	—	23,590	20,120	1.03	6.86	18.00	0.00	0.00	
19	35,770	1.79	6.93	—	23,950	20,510	1.09	6.87	18.20	0.00	0.00	
20	34,750	1.85	6.98	—	22,550	19,750	1.09	6.87	18.00	0.00	0.00	
21	35,610	2.03	6.96	—	24,170	19,420	1.16	6.85	18.00	0.00	0.00	
22	35,550	2.01	6.93	—	23,770	19,450	1.20	6.84	18.00	0.00	0.00	
23	36,050	1.80	6.90	—	23,400	20,470	1.23	6.84	17.00	0.00	0.00	
24	35,140	1.65	6.87	—	22,810	20,250	1.24	6.82	17.00	0.00	0.00	
25	36,380	1.05	6.89	—	23,810	20,630	0.46	6.79	16.80	0.00	0.00	
26	35,360	1.25	6.90	—	23,350	20,250	0.53	6.86	16.80	0.00	0.00	
27	35,080	1.28	6.89	—	23,340	19,620	0.60	6.84	16.70	0.00	0.00	
28	35,040	1.43	6.90	—	23,850	18,720	0.67	6.85	16.60	0.00	0.00	
29	36,330	1.51	6.92	—	25,070	19,510	0.71	6.88	16.60	0.00	0.00	
30	35,450	1.57	6.90	—	22,310	19,550	0.76	6.87	16.60	0.00	0.00	
31	36,860	1.82	6.89	—	23,020	20,310	0.88	6.80	16.80	0.00	0.00	
合計	1,104,850			—	737,910	612,660				0.00	0.00	
最大	37,220	2.61	6.98	—	25,070	20,950	1.42	7.00	20.10	0.00	0.00	
最小	32,790	1.05	6.85	—	21,670	16,330	0.44	6.79	16.10	0.00	0.00	
平均	35,640	1.70	6.91	—	23,804	19,763	0.93	6.87	17.16	0.00	0.00	

初野浄水場 流量水質報告書

令和4年9月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	35,460	1.86	6.88	—	23,020	19,990	0.97	6.82	14.10	0.00	0.00	
2	36,330	1.91	6.85	—	24,430	20,590	0.99	6.77	17.00	0.00	0.00	
3	34,660	1.90	6.86	—	23,870	19,440	1.02	6.75	16.00	0.00	0.00	
4	35,520	1.93	6.85	—	24,480	19,400	1.09	6.75	15.80	0.00	0.00	
5	36,790	1.13	6.83	—	25,030	19,940	0.58	6.77	16.10	0.00	0.00	
6	35,190	1.27	6.87	—	23,960	19,670	0.65	6.84	16.10	0.00	0.00	
7	34,820	1.33	6.85	—	22,870	19,690	0.73	6.85	16.10	0.00	0.00	
8	36,680	1.52	6.80	—	24,990	20,420	0.76	6.82	15.50	0.00	0.00	
9	34,250	1.72	6.83	—	23,230	18,500	0.98	6.84	16.20	0.00	0.00	
10	36,720	1.91	6.88	—	24,320	19,970	1.14	6.84	17.90	0.00	0.00	
11	35,500	1.99	6.84	—	24,140	18,810	1.20	6.85	18.20	0.00	0.00	
12	36,320	1.99	6.90	—	24,770	19,300	1.31	6.86	18.40	0.00	0.00	
13	34,010	2.04	6.90	—	23,100	18,930	1.30	6.85	18.40	0.00	0.00	
14	37,870	2.08	6.90	—	25,040	21,150	1.33	6.89	18.60	0.00	0.00	
15	33,750	2.14	6.88	—	22,990	18,630	1.38	6.86	18.40	0.00	0.00	
16	35,190	2.17	6.89	—	23,290	19,310	1.43	6.92	18.40	0.00	0.00	
17	36,320	2.14	6.90	—	24,270	20,300	1.44	6.91	18.60	0.00	0.00	
18	35,370	2.07	6.90	—	24,510	19,520	1.47	6.86	18.70	0.00	0.00	
19	35,550	2.06	6.86	—	24,890	19,200	1.39	6.83	18.80	0.00	0.00	
20	35,860	2.00	6.84	—	24,670	19,470	1.40	6.87	18.80	0.00	0.00	
21	35,650	2.10	6.84	—	24,870	19,800	1.41	6.85	18.30	0.00	0.00	
22	34,920	1.21	6.88	—	23,710	18,900	0.61	6.87	18.00	0.00	0.00	
23	35,740	1.23	6.88	—	24,110	19,610	0.70	6.89	18.10	0.00	0.00	
24	35,380	1.43	6.85	—	24,620	19,380	0.77	6.76	18.20	0.00	0.00	
25	35,560	1.65	6.85	—	25,420	19,220	1.08	6.84	18.00	0.00	0.00	
26	36,700	1.63	6.88	—	24,880	19,540	1.14	6.86	18.20	0.00	0.00	
27	33,900	1.67	6.88	—	23,280	19,050	1.16	6.88	18.10	0.00	0.00	
28	36,060	1.74	6.86	—	24,080	20,140	1.09	6.88	18.10	0.00	0.00	
29	35,750	1.80	6.89	—	23,790	19,980	1.11	6.93	18.10	0.00	0.00	
30	35,970	1.82	6.88	—	24,000	20,190	1.20	6.94	18.10	0.00	0.00	
合計	1,067,790			—	724,630	588,040				0.00	0.00	
最大	37,870	2.17	6.90	—	25,420	21,150	1.47	6.94	18.80	0.00	0.00	
最小	33,750	1.13	6.80	—	22,870	18,500	0.58	6.75	14.10	0.00	0.00	
平均	35,593	1.78	6.87	—	24,154	19,601	1.09	6.85	17.58	0.00	0.00	

初野浄水場 流量水質報告書

令和4年10月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	35,420	1.91	6.89	—	24,240	19,810	1.18	6.92	18.10	0.00	0.00	
2	35,670	1.92	6.90	—	24,250	19,290	1.34	6.92	18.10	0.00	0.00	
3	35,640	1.92	6.88	—	24,360	19,180	1.29	6.86	18.10	0.00	0.00	
4	35,890	1.96	6.85	—	24,510	20,070	1.30	6.90	17.30	0.00	0.00	
5	36,210	1.95	6.82	—	24,640	20,440	1.27	6.87	17.10	0.00	0.00	
6	34,440	1.16	6.80	—	23,520	18,600	0.59	6.85	16.70	0.00	0.00	
7	36,980	1.19	6.84	—	25,280	20,040	0.73	6.94	16.40	0.00	0.00	
8	34,290	1.41	6.80	—	22,850	18,570	0.81	0.86	16.40	0.00	0.00	
9	36,510	1.48	6.78	—	24,810	19,600	0.89	6.83	16.40	0.00	0.00	
10	34,330	1.63	6.80	—	24,090	18,000	0.97	6.80	16.40	0.00	0.00	
11	35,590	1.72	6.82	—	24,740	19,160	1.03	6.87	16.40	0.00	0.00	
12	36,270	1.84	6.83	—	24,190	20,400	1.07	6.88	16.40	0.00	0.00	
13	34,810	1.93	6.85	—	23,850	19,230	1.11	6.91	16.20	0.00	0.00	
14	35,980	1.97	6.84	—	23,880	19,600	1.11	6.89	15.90	0.00	0.00	
15	35,000	1.31	6.87	—	23,290	19,470	0.65	6.90	15.90	0.00	0.00	
16	35,560	1.37	6.90	—	24,310	19,370	0.76	6.92	16.00	0.00	0.00	
17	35,240	1.50	6.90	—	24,060	18,990	0.78	6.90	16.00	0.00	0.00	
18	35,620	1.63	6.83	—	24,170	19,660	0.86	6.95	16.20	0.00	0.00	
19	34,620	1.64	6.89	—	23,140	18,700	1.09	6.96	15.90	0.00	0.00	
20	35,470	1.75	6.91	—	24,110	19,370	0.93	7.00	15.80	0.00	0.00	
21	36,080	1.35	6.90	—	22,670	19,730	0.63	6.99	15.80	0.00	0.00	
22	36,380	1.35	6.87	—	23,510	19,760	0.67	6.97	15.90	0.00	0.00	
23	36,500	1.45	6.90	—	25,070	19,560	0.75	6.93	15.80	0.00	0.00	
24	36,310	1.57	6.81	—	25,040	19,180	0.76	6.90	15.60	0.00	0.00	
25	34,710	1.62	6.89	—	23,620	18,660	0.85	6.95	15.30	0.00	0.00	
26	34,280	1.72	6.86	—	23,090	18,630	0.89	6.87	15.00	0.00	0.00	
27	37,280	1.79	6.88	—	24,740	20,130	0.93	6.95	14.90	0.00	0.00	
28	34,970	1.94	6.86	—	22,770	18,610	1.02	6.94	14.80	0.00	0.00	
29	36,020	2.00	6.87	—	24,140	19,560	1.08	6.93	14.80	0.00	0.00	
30	35,170	2.09	6.91	—	23,380	18,470	1.17	6.97	14.60	0.00	0.00	
31	35,690	2.17	6.90	—	24,420	19,000	1.25	6.99	14.60	0.00	0.00	
合計	1,102,930			—	744,740	598,840				0.00	0.00	
最大	37,280	2.17	6.91	0.00	25,280	20,440	1.34	7.00	18.10	0.00	0.00	
最小	34,280	1.16	6.78	0.00	22,670	18,000	0.59	0.86	14.60	0.00	0.00	
平均	35,578	1.69	6.86	—	24,024	19,317	0.96	6.72	16.09	0.00	0.00	

初野浄水場 流量水質報告書

令和4年11月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	35,600	2.25	6.89	—	24,090	19,360	1.31	6.95	14.50	0.00	0.00	
2	36,360	2.26	6.89	—	24,560	19,620	1.34	6.96	14.60	0.00	0.00	
3	35,540	1.52	6.89	—	22,910	18,930	1.45	6.99	14.50	0.00	0.00	
4	35,710	1.59	6.85	—	23,890	19,290	1.45	6.97	14.40	0.00	0.00	
5	36,620	1.39	6.90	—	24,300	19,610	0.87	7.00	14.20	0.00	0.00	
6	36,340	1.53	6.92	—	24,180	18,990	0.95	7.01	14.00	0.00	0.00	
7	40,130	1.60	6.88	—	26,410	20,850	1.01	7.00	14.10	0.00	0.00	
8	31,780	1.68	6.87	—	20,860	16,980	1.10	6.97	13.80	0.00	0.00	
9	37,170	1.75	6.85	—	24,240	19,970	1.17	6.98	13.80	0.00	0.00	
10	35,730	1.83	6.90	—	23,050	18,970	1.31	7.04	13.70	0.00	0.00	
11	34,860	1.99	6.89	—	23,150	18,670	1.49	7.00	13.70	0.00	0.00	
12	37,240	2.00	6.88	—	24,490	19,810	1.37	6.98	13.70	0.00	0.00	
13	35,690	1.99	6.88	—	23,710	18,950	1.33	7.01	13.70	0.00	0.00	
14	35,150	2.00	6.91	—	23,500	17,430	1.42	7.03	13.60	0.00	0.00	
15	36,820	2.06	6.90	—	24,050	18,710	1.44	7.02	13.40	0.00	0.00	
16	35,410	2.05	6.90	—	23,680	17,970	1.69	7.03	13.20	0.00	0.00	
17	36,970	1.28	6.91	—	23,770	18,920	0.68	7.04	13.10	0.00	0.00	
18	36,380	1.42	6.93	—	23,890	18,220	0.75	7.06	12.90	0.00	0.00	
19	36,630	1.78	6.87	—	23,360	18,310	0.75	7.04	12.80	0.00	0.00	
20	36,470	1.56	6.91	—	24,350	18,260	0.78	7.06	12.80	0.00	0.00	
21	36,050	1.59	6.89	—	23,790	18,180	0.85	7.03	12.80	0.00	0.00	
22	35,990	1.62	6.89	—	23,740	18,850	0.85	7.04	12.70	0.00	0.00	
23	36,620	1.64	6.89	—	23,900	18,950	0.88	7.03	12.60	0.00	0.00	
24	37,470	1.81	6.88	—	25,140	19,410	0.93	7.01	12.50	0.00	0.00	
25	37,430	1.84	6.91	—	24,020	19,220	1.10	7.08	12.50	0.00	0.00	
26	34,990	1.84	6.91	—	22,790	18,330	1.07	7.07	12.30	0.00	0.00	
27	36,650	1.85	6.87	—	24,390	19,120	1.06	7.06	12.30	0.00	0.00	
28	36,470	1.77	6.92	—	24,450	17,970	1.05	7.09	12.10	0.00	0.00	
29	36,620	1.90	6.88	—	23,940	19,130	1.12	7.06	12.20	0.00	0.00	
30	37,460	1.87	6.91	—	24,780	20,010	1.32	7.07	12.40	0.00	0.00	
合計	1,088,350			—	717,380	566,990				0.00	0.00	
最大	40,130	2.26	6.93		26,410	20,850	1.69	7.09	14.60	0.00	0.00	
最小	31,780	1.28	6.85		20,860	16,980	0.68	6.95	12.10	0.00	0.00	
平均	36,278	1.78	6.89	—	23,913	18,900	1.13	7.02	13.30	0.00	0.00	

初野浄水場 流量水質報告書

令和4年12月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	35,820	1.92	6.91	—	24,330	18,650	1.16	7.07	12.10	0.00	0.00	
2	36,880	1.93	6.92	—	24,790	19,470	1.26	7.05	11.70	0.00	0.00	
3	35,730	1.94	6.93	—	23,840	18,600	1.23	7.07	11.30	0.00	0.00	
4	36,780	2.07	6.91	—	24,820	19,070	1.39	7.06	11.40	0.00	0.00	
5	36,370	2.11	6.90	—	23,970	19,070	1.32	7.06	11.20	0.00	0.00	
6	36,370	2.10	6.91	—	24,170	19,320	1.36	7.07	10.90	0.00	0.00	
7	35,840	1.51	6.93	—	23,510	19,140	0.79	7.07	10.80	0.00	0.00	
8	38,270	1.60	6.94	—	25,160	20,950	0.85	7.08	10.80	0.00	0.00	
9	36,370	1.65	6.94	—	23,850	19,450	0.91	7.09	10.60	0.00	0.00	
10	36,980	1.80	6.92	—	23,850	19,520	1.03	7.09	10.60	0.00	0.00	
11	34,360	1.88	6.91	—	22,940	17,820	1.13	7.05	10.40	0.00	0.00	
12	36,010	1.84	6.91	—	24,540	18,800	1.16	7.07	10.20	0.00	0.00	
13	37,350	3.22	6.63	—	24,120	19,155	1.94	6.76	7.90	0.00	0.00	
14	35,830	3.55	6.62	—	23,180	19,155	2.38	6.73	7.70	0.00	0.00	
15	36,600	2.22	6.77	—	23,220	19,155	1.42	6.97	9.20	0.00	0.00	
16	36,820	1.95	6.86	—	24,080	19,080	1.22	7.09	9.50	0.00	0.00	
17	35,760	1.99	6.87	—	22,920	19,180	1.29	7.07	9.40	0.00	0.00	
18	34,360	2.16	6.90	—	22,800	19,290	1.33	7.06	9.30	0.00	0.00	
19	37,810	1.80	6.92	—	25,160	19,450	1.15	7.08	9.00	0.00	0.00	
20	35,500	1.84	6.90	—	22,890	18,790	1.10	7.08	8.80	0.00	0.00	
21	36,870	2.07	6.85	—	23,340	20,120	1.23	7.07	8.70	0.00	0.00	
22	37,060	2.32	6.84	—	23,580	20,650	1.47	7.08	8.80	0.00	0.00	
23	35,440	2.54	6.86	—	23,150	19,960	1.47	7.13	8.60	0.00	0.00	
24	36,730	2.54	6.85	—	23,350	20,400	1.57	7.10	8.30	0.00	0.00	
25	35,660	2.62	6.88	—	23,130	19,380	1.68	7.10	8.30	0.00	0.00	
26	37,600	2.70	6.95	—	23,300	20,580	1.77	7.13	8.20	0.00	0.00	
27	34,770	2.70	6.92	—	21,290	19,480	1.59	7.16	7.90	0.00	0.00	
28	38,840	2.92	6.92	—	24,150	20,900	1.81	7.13	8.00	0.00	0.00	
29	37,850	3.75	6.90	—	24,320	20,260	2.44	7.08	7.90	0.00	0.00	
30	36,620	3.25	6.90	—	22,000	19,190	2.15	7.09	7.60	0.00	0.00	
31	37,570	3.22	6.90	—	23,380	19,230	2.16	7.10	7.60	0.00	0.00	
合計	1,130,820			—	733,130	603,265				0.00	0.00	
最大	38,840	3.75	6.95	—	25,160	20,950	2.44	7.16	12.10	0.00	0.00	
最小	34,360	1.51	6.62	—	21,290	17,820	0.79	6.73	7.60	0.00	0.00	
平均	36,478	2.31	6.88	—	23,649	19,460	1.44	7.06	9.44	0.00	0.00	

初野浄水場 流量水質報告書

令和5年1月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	37,920	3.55	6.93	—	23,840	19,210	2.46	7.13	7.60	0.00	0.00	
2	36,840	3.45	6.93	—	24,150	18,810	2.34	7.11	7.40	0.00	0.00	
3	37,460	3.88	6.89	—	24,840	19,120	2.67	7.08	7.20	0.00	0.00	
4	37,710	3.67	6.91	—	24,870	19,280	2.48	7.11	7.00	0.00	0.00	
5	37,300	3.65	6.92	—	24,540	19,300	2.64	7.09	6.90	0.00	0.00	
6	36,820	3.72	6.91	—	23,210	20,130	2.74	7.08	6.80	0.00	0.00	
7	36,670	3.64	6.93	—	22,750	19,660	2.62	7.09	6.70	0.00	0.00	
8	37,470	4.20	6.89	—	23,920	19,780	2.99	7.13	6.60	0.00	0.00	
9	36,150	3.80	6.88	—	23,730	19,220	2.79	7.13	6.50	0.00	0.00	
10	36,220	3.58	6.91	—	24,010	19,630	2.65	7.14	6.50	0.00	0.00	
11	36,730	3.98	6.95	—	23,090	19,610	2.99	7.17	6.30	0.00	0.00	
12	36,340	3.33	6.95	—	22,840	19,820	2.56	7.19	6.30	0.00	0.00	
13	37,560	3.42	6.95	—	23,470	20,860	2.51	7.20	6.40	0.00	0.00	
14	35,960	3.89	6.94	—	22,870	20,360	2.88	7.17	6.60	0.00	0.00	
15	37,780	3.63	6.94	—	24,900	20,350	2.75	7.14	6.60	0.00	0.00	
16	35,370	3.68	6.94	—	23,220	18,730	2.83	7.16	6.50	0.00	0.00	
17	37,110	3.04	6.94	—	24,150	20,670	2.13	7.18	6.50	0.00	0.00	
18	37,940	3.12	6.97	—	24,050	20,820	2.60	7.19	6.40	0.00	0.00	
19	34,300	2.99	6.98	—	21,700	18,830	2.16	7.17	6.20	0.00	0.00	
20	38,020	3.34	7.02	—	24,140	21,090	2.45	7.18	6.20	0.00	0.00	
21	35,460	3.12	7.03	—	22,100	19,810	2.28	7.18	6.10	0.00	0.00	
22	36,600	3.22	7.07	—	23,350	19,370	2.32	7.19	5.90	0.00	0.00	
23	36,990	3.28	7.07	—	24,170	19,220	2.44	7.19	5.90	0.00	0.00	
24	36,160	3.21	7.06	—	23,270	19,810	2.51	7.18	5.90	0.00	0.00	
25	36,630	3.61	7.02	—	23,150	19,810	3.16	7.20	5.60	0.00	0.00	
26	35,900	3.22	7.05	—	22,440	19,260	2.47	7.19	5.40	0.00	0.00	
27	39,360	3.18	7.09	—	22,430	20,620	2.42	7.23	5.30	0.00	0.00	
28	37,910	3.26	7.02	—	22,730	19,590	2.49	7.24	5.20	0.00	0.00	
29	39,620	3.17	7.14	—	24,370	19,990	2.50	7.25	5.10	0.00	0.00	
30	37,050	3.14	7.16	—	23,070	19,030	2.32	7.26	5.10	0.00	0.00	
31	36,060	3.04	7.16	—	22,100	19,950	2.25	7.24	4.90	0.00	0.00	
最大	39,620	4.20	7.16	—	24,900	21,090	3.16	7.26	7.60	0.00	0.00	
最小	34,300	2.99	6.88	—	21,700	18,730	2.13	7.08	4.90	0.00	0.00	
合計	1,145,410			—	727,470	611,740				0.00	0.00	
平均	36,949	3.45	6.99	—	23,467	19,734	2.56	7.17	6.25	0.00	0.00	

初野浄水場 流量水質報告書

令和5年2月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	36,700	3.05	7.20	—	23,020	20,790	2.26	7.28	4.90	0.00	0.00	
2	36,680	2.79	7.20	—	22,080	20,140	2.12	7.28	5.10	0.00	0.00	
3	34,690	2.98	7.19	—	21,050	18,750	2.22	7.25	4.90	0.00	0.00	
4	37,990	2.88	7.24	—	23,160	20,670	2.17	7.25	4.90	0.00	0.00	
5	35,660	2.89	7.20	—	21,660	19,270	2.12	7.20	4.80	0.00	0.00	
6	36,150	2.68	7.23	—	21,960	19,560	2.02	7.28	4.90	0.00	0.00	
7	36,650	2.74	7.24	—	22,650	20,400	2.03	7.29	5.10	0.00	0.00	
8	36,990	3.16	7.18	—	23,520	20,050	2.44	7.24	5.10	0.00	0.00	
9	36,160	3.51	7.17	—	22,640	19,610	2.50	7.24	4.90	0.00	0.00	
10	37,530	3.27	7.21	—	23,590	20,580	2.45	7.25	4.70	0.00	0.00	
11	35,480	3.04	7.19	—	22,490	19,220	2.22	7.26	4.70	0.00	0.00	
12	36,060	3.11	7.23	—	22,830	18,960	2.24	7.29	4.80	0.00	0.00	
13	36,550	2.96	7.22	—	23,720	19,690	2.15	7.28	4.90	0.00	0.00	
14	35,870	2.98	7.19	—	22,950	19,430	2.20	7.25	4.80	0.00	0.00	
15	37,930	3.22	7.20	—	23,990	20,150	2.49	7.25	4.80	0.00	0.00	
16	35,840	2.50	7.45	—	22,060	19,520	1.75	7.53	4.60	0.00	0.00	
17	36,360	2.55	7.49	—	22,110	19,600	1.77	7.56	4.70	0.00	0.00	
18	33,220	2.46	7.50	—	20,310	18,060	1.69	7.50	4.70	0.00	0.00	
19	35,520	2.74	7.48	—	22,350	19,140	1.79	7.55	4.70	0.00	0.00	
20	38,050	2.62	7.47	—	24,460	19,930	1.72	7.56	5.20	0.00	0.00	
21	34,050	2.82	7.46	—	21,850	18,990	1.97	7.55	4.90	0.00	0.00	
22	38,010	2.79	7.46	—	24,200	20,640	1.94	7.56	4.90	0.00	0.00	
23	34,350	2.71	7.50	—	21,530	18,870	1.87	7.59	4.80	0.00	0.00	
24	36,530	2.77	7.50	—	23,140	19,780	1.95	7.59	4.80	0.00	0.00	
25	36,400	3.11	7.48	—	23,050	19,940	2.23	7.50	5.00	0.00	0.00	
26	35,260	3.07	7.46	—	22,740	18,930	2.13	7.56	4.80	0.00	0.00	
27	36,850	3.43	7.50	—	23,680	19,970	2.37	7.58	4.80	0.00	0.00	
28	35,020	3.33	7.53	—	21,870	18,990	2.31	7.60	4.80	0.00	0.00	
最大	38,050	3.51	7.53	—	24,460	20,790	2.50	7.60	5.20	0.00	0.00	
最小	33,220	2.46	7.17	—	20,310	18,060	1.69	7.20	4.60	0.00	0.00	
合計	1,012,550			—	634,660	549,630				0.00	0.00	
平均	36,163	2.93	7.33	—	22,666	19,630	2.11	7.40	4.86	0.00	0.00	

初野浄水場 流量水質報告書

令和5年3月分

項目 日	原 水 関 係				沈澱池 流量 (m3/日)	配 水 関 係				薬品注入量(1)		記事
	原水量 (m3/日)	濁度 (ppm)	P H	アルカ リ 度		配水量 (m3/日)	濁度 (ppm)	P H	水温 (° C)	P A C	苛性 ソーダ	
1	36,390	3.16	7.51	—	22,560	20,150	2.17	7.59	5.20	0.00	0.00	
2	36,410	3.05	7.51	—	22,820	20,280	2.11	7.58	5.40	0.00	0.00	
3	35,150	3.01	7.49	—	22,340	19,390	2.06	7.57	5.30	0.00	0.00	
4	36,110	3.01	7.52	—	23,180	19,930	2.06	7.59	5.40	0.00	0.00	
5	36,060	3.13	7.51	—	23,060	19,730	2.10	7.57	5.40	0.00	0.00	
6	36,430	3.26	7.49	—	23,790	19,870	2.38	7.55	5.30	0.00	0.00	
7	35,090	3.20	7.48	—	22,410	19,570	2.36	7.55	5.30	0.00	0.00	
8	37,260	3.09	7.49	—	23,530	20,790	2.20	7.56	5.70	0.00	0.00	
9	35,190	2.83	7.50	—	22,160	19,790	2.06	7.54	6.00	0.00	0.00	
10	35,560	2.94	7.47	—	22,510	19,530	2.09	7.52	5.80	0.00	0.00	
11	37,930	2.74	7.50	—	26,550	21,070	1.87	7.57	6.40	0.00	0.00	
12	35,070	2.86	7.47	—	20,510	18,680	1.94	7.53	6.20	0.00	0.00	
13	35,090	2.70	7.47	—	22,820	18,830	1.87	7.53	6.30	0.00	0.00	
14	36,780	2.69	7.47	—	24,100	20,310	1.78	7.54	6.50	0.00	0.00	
15	35,880	2.61	7.47	—	23,500	19,460	1.81	7.54	6.20	0.00	0.00	
16	36,000	2.59	7.46	—	23,050	19,320	1.85	7.53	6.20	0.00	0.00	
17	35,870	2.61	7.46	—	23,060	19,780	1.77	7.53	6.50	0.00	0.00	
18	36,320	2.62	7.43	—	23,510	20,110	1.81	7.51	6.20	0.00	0.00	
19	36,040	2.54	7.46	—	24,260	19,200	1.75	7.53	6.30	0.00	0.00	
20	36,660	2.60	7.46	—	23,800	19,760	1.78	7.54	6.50	0.00	0.00	
21	36,210	2.06	7.44	—	23,580	20,330	1.49	7.52	6.70	0.00	0.00	
22	36,390	2.02	7.45	—	23,710	20,340	1.43	7.51	6.90	0.00	0.00	
23	34,380	2.01	7.46	—	22,390	18,890	1.36	7.50	7.00	0.00	0.00	
24	36,650	2.07	7.45	—	23,810	20,460	1.39	7.50	7.30	0.00	0.00	
25	35,900	2.25	7.41	—	24,090	20,270	1.49	7.50	7.60	0.00	0.00	
26	35,580	2.28	7.42	—	23,930	19,530	1.48	7.47	7.10	0.00	0.00	
27	35,520	2.24	7.48	—	23,650	19,270	2.05	7.53	7.60	0.00	0.00	
28	35,590	2.50	7.41	—	23,630	19,840	1.64	7.50	7.50	0.00	0.00	
29	36,930	2.43	7.43	—	23,940	20,240	1.64	7.50	7.40	0.00	0.00	
30	35,880	2.37	7.44	—	23,500	19,330	1.55	7.51	7.50	0.00	0.00	
31	35,440	2.42	7.44	—	23,020	19,070	1.58	7.50	7.70	0.00	0.00	
合計	1,115,760			—	722,770	613,120				0.00	0.00	
最大	37,930	3.26	7.52	—	26,550	21,070	2.38	7.59	7.70	0.00	0.00	
最小	34,380	2.01	7.41	—	20,510	18,680	1.36	7.47	5.20	0.00	0.00	
平均	35,992	2.64	7.47	—	23,315	19,778	1.84	7.53	6.40	0.00	0.00	